

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NW 1/4 NE 1/4 SW 1/4	Section number 9	Township number T 30 S	Range number R 30 E
2. Distance and direction from nearest town or city: 6 1/2 mi N of Plains			3. Owner of well: Ron Wilcox			
Street address of well location if in city:			R.R. or street: Plains			
			City, state, zip code: Kans 67869			
4. Locate with "X" in section below:					6. Bore hole dia. 8 3/8 in. Completion date 4-22-81 Well depth 260 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material _____ Height: 24 or below Threaded _____ Welded _____ Surface 24 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 260 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 40sch	
					10. Screen: Manufacturer's name Pumpco Type PVC Dia. 5" Slot/gauze 1/2 Length 40 Set between 220 ft. and 260 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4-1/8	
Topsoil					11. Static water level: _____ mo./day/yr. 170 ft. below land surface Date 4-22-81	
sandy clay					12. Pumping level below land surfaces: 170 ft. after 1 1/2 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.	
brown clay					13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
coarse sand					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade	
brown clay					15. Well grouted? Yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.	
sand					16. Nearest source of possible contamination: ft. 100 Direction N Type Corrals Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
sand rock					17. Pump: _____ Not installed Manufacturer's name FLINT WALLING Model number 78A13 HP 3/4 Volts 120V Length of drop pipe 200 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Robert Dely 101A Business name _____ License No. _____ Address Meade Signed Robert Bartel Date 6-20-81 Authorized representative	
18. Elevation:					19. Remarks:	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5