

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>MEADE</u>	Fraction <u>SW 1/4 NE 1/4 SW 1/4</u>	Section number <u>14</u>	Township number T <u>31</u> S R <u>30</u> <u>1/4 NW</u>	Range number
2. Distance and direction from nearest town or city: <u>South of Copeland</u> <u>1/2 mi. to 2nd curve, 9 South 2 East, 1/2 South</u> Street address of well location if in city:				3. Owner of well: <u>Jay Borth</u> R.R. or street: <u>Meade, Ks.</u> City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>11-1-75</u> Well depth <u>412</u> ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.07</u> lbs./ft. Dia. <u>6</u> in. to <u>412</u> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <input type="checkbox"/>		
				10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>76"</u> Slot/gauge <input type="checkbox"/> Length <u>20'</u> Set between <u>380</u> ft. and <u>400</u> ft. Perforations <u>300-310</u> and <u>350-380, 400-412</u> Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4" Down</u>		
				11. Static water level: <u>145</u> ft. below land surface Date <input type="checkbox"/> mo./day/yr.		
				12. Pumping level below land surfaces: <u>176</u> ft. after <u>2</u> hrs. pumping <u>869</u> g.p.m. <u>192</u> ft. after <u>4</u> hrs. pumping <u>1342</u> g.p.m. Estimated maximum yield <u>1340</u> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <u>yes</u> Inches above grade		
				15. Well grouted? <input type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft. <u>N/A</u>		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Goulds-US Pumps</u> Model number <input type="checkbox"/> HP <u>200</u> Volts <input type="checkbox"/> Length of drop pipe <u>260</u> ft. capacity <u>1300</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter-Wilson Drilling</u> Business name <u>F.O.B. A Garden City, Ks</u> license No. <input type="checkbox"/> Address <input type="checkbox"/> Signed <u>[Signature]</u> Date <u>5-4-75</u> Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

31 300W 14 SW NE SW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Jay Borth
Meade County
10-7-75

Location: SW 14-31-30
½ mile North, ½ mile East, ¼ mile North of Test
1

Static Water Level: 150

Test # 2

0	2	Top Soil
2	92	Brown Sandy Clay
92	230	Fine to Med. Sand & Gravel (Loose)
230	286	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
286	310	Fine to Med. Sand & Gravel (Loose)
310	355	Blue Clay mixed with Brown Sandy Clay
355	412	Fine to Med. Sand & Gravel (Loose)
412	440	Brown Sandy Clay

TD 412'