


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 32	Township number T 31 S R 30	Range number EW
2. Distance and direction from nearest town or city: 2 miles N, 1 1/2 W, 1/2 N, of Plains, Kansas Street address of well location if in city:			3. Owner of well: Gerald Jacobs R.R. or street: R R City, state, zip code: Plains Kansas			
4. Locate with "X" in section below: Sketch map:  <p style="text-align: center;">NW corner of the SE¹/₄, Sec. 32, T31S, R30W, Meade Co., Kansas</p>			6. Bore hole dia. 28 in. Completion date 4-29-76 Well depth 426 ft.			
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top soil			0	3	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Tan clay, sand streaks			3	122	9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 224 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 219	
Tan clay			122	134	10. Screen: Manufacturer's name Doerr, Brown and Foster Type Louver and Dia. 16" Millislot Slot/gauze 1/8" Length 202' Set between 224 ft. and 426 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 4.4mm	
Fine to coarse sand			134	176	11. Static water level: <input type="checkbox"/> mo./day/yr. 156 ft. below land surface Date 1-28-76	
Tan clay			176	186	12. Pumping level below land surfaces: 180 ft. after 1 hrs. pumping 1924 g.p.m. 181 ft. after 1 hrs. pumping 1953 g.p.m. Estimated maximum yield 2000 g.p.m.	
Tan clay, sand streaks			186	220	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>	
Fine to coarse sand small clay streaks			220	360	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade	
Tan clay			360	376	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Coarse sand fine gravel			376	400	16. Nearest source of possible contamination: Unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Fine to coarse sand clay streaks			400	426	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 14TL HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 280 ft. capacity 2000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Tan clay and limestone			426	480	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne - Western Co. 150 Business name License No. Address Garden City Signed <i>[Signature]</i> Date 5-21-76 Authorized representative	
Fine to medium sand			480	496		
Tan clay brown sandstone streaks			496	518		
Red bed			518	540		
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 31 S R 30 E
 Sec 32
 NW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5