

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 35	Township number T 31 S R 30 E/W	Range number
2. Distance and direction from nearest town or city: 3 N, 2 E, at Plains, Kansas. Street address of well location if in city:				3. Owner of well: Mrs. Gano Pearson R.R. or street: Box 1 City, state, zip code: Garden City, Kansas 67846		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date _____ Well depth 420 ft. 11/8/76		
		<p style="text-align: center;">561' S of NW corner of the NW 1/4, Sec. 35, T31S, R30W, Meade County, Kansas.</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top soil				0	22	9. Casing: Material <u>stl</u> Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP _____ PVC _____ Weight <u>37</u> lbs./ft. Dia. <u>16</u> in. to <u>180</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>219</u>
Tan and white clay with sand streaks XX				22	143	10. Screen: Manufacturer's name <u>Foster, Doerr</u> Type <u>louver, millslot 167</u> Slot/gauze <u>1/8"</u> Length <u>240'</u> Set between <u>180</u> ft. and <u>420</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> <u>yes</u> Size range of material <u>4.4mm</u>
Fine to coarse sand				143	198	11. Static water level: _____ mo./day/yr. <u>178</u> ft. below land surface Date <u>9/8/76</u>
Tan clay with sand streaks				198	218	12. Pumping level below land surfaces: <u>198</u> ft. after <u>1/2</u> hrs. pumping <u>1080</u> g.p.m. <u>230</u> ft. after <u>1</u> hrs. pumping <u>2216</u> g.p.m. Estimated maximum yield <u>2200</u> g.p.m.
Fine to coarse sand				218	262	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
Tan clay with sand streaks				262	286	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ inches above grade
Fine to coarse sand				286	348	15. Well grouted? <input checked="" type="checkbox"/> <u>yes</u> With: _____ Neat cement <input checked="" type="checkbox"/> <u>1</u> Bentonite _____ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
Blue clay with sand streaks				348	390	16. Nearest source of possible contamination: <u>unk</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> <u>X</u> Yes _____ No
Fine to coarse sand				390	420	17. Pump: _____ Not installed Manufacturer's name <u>Layne & Bowler</u> Model number <u>14 TL</u> HP <u>150</u> Volts _____ Length of drop pipe <u>260</u> ft. capacity <u>2000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> <u>Turbine</u> <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Tan clay with limestone streaks				420	496	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Layne-Western Co., Inc. 102</u> Business name _____ License No. _____ Address <u>Garden City, Kansas</u> Signed <u>[Signature]</u> Date <u>1 Dec 76</u> Authorized representative
Red bed				496	520	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

T 31 S R 30 E/W
 Sec 35
 NW 1/4
 NW 1/4
 NW 1/4