

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Kaufman 1-15

CWV Inv. # 12356

1. Location of well:		County Seward	Fraction 1/4 C-SW 4 NE 1/4	Section number 15	Township number T 31 S R 31	Range number E/W
2. Distance and direction from nearest town or city: 4 north of Kismet, 6 east, 1/2 east		3. Owner of well: Sage Drilling Company		R.R. or street: 500 Bitting Bldg.		
Street address of well location if in city:		City, state, zip code: Wichita, Kansas 67202				
4. Locate with "X" in section below:		Sketch map showing location			6. Bore hole dia. 3 1/2 7" in. Completion date 6-4 Well depth 300 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	2	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 28 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.78 lbs./ft. Dia. 5 in. to 215 ft. depth Wall Thickness: inches or Dia. 5 in. to 300 ft. depth gage No. 265		
Sandy clay		2	103	10. Screen: Manufacturer's name _____ sawed perf. Type PVC Dia. 5 1/2 Slot/gauze .030 Length 80 Set between 215 ft. and 295 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/8 to 3/16		
Clay, Fine sand & Med. to large sand		103	180	11. Static water level: 180 ft. below land surface Date 6-4-76 mp./day/yr.		
Clay and med. to large sand 30-70		180	220	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.		
Clay and Med. to large sand 15-85		220	255	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Clay, Fine sand & Med. to large sand		255	275	14. Well head completion: <input type="checkbox"/> Pitless adapter 28 inches above grade		
Clay and Med. to large sand 10-90		275	300	15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
(Use a second sheet if needed)				16. Nearest source of possible contamination: ft. 100 Direction NE Type oilwell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carlile Water Well 118 Business name _____ License No. _____ Address Box 275, Liberal, Ks. Signed Edward E. Means Date 6-23 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

31 31 W 15 CSWNE 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5