


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 32	Township number T 31 S	Range number R 31 E
2. Distance and direction from nearest town or city: 8 Miles W and 2 1/2 miles N of Plains Street address of well location if in city:			3. Owner of well: Mrs. Keith Rosson R.R. or street: City, state, zip code: Plains, Kansas		
4. Locate with "X" in section below: N  W E S 1 Mile			Sketch map: 430' W and 1650' N of the SE corner of the NW 1/4, Sec. 32, T31S R31W, Seward County, Kansas		
5. Type and color of material			From	To	6. Bore hole dia. 28 in. Completion date 3-13-76 Well depth 418 ft.
Top soil			0	3	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Tan clay			3	46	8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Fine to coarse sand			46	66	9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 18 1/2 in. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
					10. Screen: Manufacturer's name Brown and Doerr Type Louver Dia. 16 in. Slot/gauze 1/8 in. Length 234 ft. Set between 184 ft. and 418 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 3.4mm
					11. Static water level: <input type="checkbox"/> mo./day/yr. 184 ft. below land surface Date 12-10-75
					12. Pumping level below land surfaces: 194 ft. after 1 hrs. pumping 1040 g.p.m. 210 ft. after 1 hrs. pumping 2340 g.p.m. Estimated maximum yield 3000 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
					15. Well grouted? Yes With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: Unk ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 14TL HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 280 ft. capacity 2000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. Inc. 150 Business name License No. Address Garden City, Kansas Signed [Signature] Date 10 May 76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5