


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 7	Township number T 31 S R 32 E/W	Range number
2. Distance and direction from nearest town or city: 75, 2 E 1/4			3. Owner of well: Harold Stapelton Estate		
Street address of well location if in city: of Sublette.			R.R. or street: City, state, zip code: Sublette, Kansas 67877		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 9 7/8 in. Completion date _____ Well depth 397 ft. 12-09-76
Top soil			0	8	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Clay			8	42	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy clay			42	63	9. Casing: Material PVC Height: Above or below _____ Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 397 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 265
Med. to lar. sand & gravel			63	100	10. Screen: Manufacturer's name _____ Jess & Lowell Type PVC Dia. 5" Slot 3/8" 1/8" Length 80' / 160' Set between 237 ft. and 397 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/16"
Med. to lar. sand & clay			100	108	11. Static water level: _____ mo./day/yr. 206 ft. below land surface Date 11/19/76
Med. to lar. sand			108	405	12. Pumping level below land surfaces: 206 ft. after _____ hrs. pumping 30-40 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
					14. Well head completion: <input checked="" type="checkbox"/> Pitless unit _____ inches above grade
					15. Well grouted? yes With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 10 Direction SE Type old well Well disinfected upon completion? yes Yes _____ No _____
					17. Pump: _____ Not installed Manufacturer's name Aermotor Model number SD19 HP 3 Volts 220 Length of drop pipe 294 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. _____ Address Meade, Kansas 67864 Signed <i>[Signature]</i> Date 12-16-76 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 31 S R 32 E/W
 Sec 7
 NE SE NE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5