

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Seward		Fraction NW 1/4 NW 1/4 SE 1/4	Section number 20	Township number T 31 S	Range number R 32 E/W
Distance and direction from nearest town or city: 12 E. Plains Street address of well location if in city: Plains, Kansas			3. Owner of well: Charon Mills R.R. or street: % Hutchinson National Bank Box 1298 City, state, zip code: Dodge City, Kansas 6-26-76		
4. Locate with "X" in section below: N NW NE SW SE S E Sketch map: NW corner of the SE 1/4, Sec. 20, T31S, R32W, Seward Co., Kansas			6. Bore hole dia. 28 in. Completion date 6-26-76 Well depth 434 ft.		
			7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: ___ Domestic ___ Public supply ___ Industry <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other		
			9. Casing: Material STI Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP ___ PVC ___ Weight 37 lbs./ft. Dia. 16 in. to 193 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. .219		
5. Type and color of material			10. Screen: Manufacturer's name Doerr, Foster		
Top soil			Type Louver, Millslot 16"		
Tan clay			Slot/gauze 1/8" Length 241		
Sandy tan clay			Set between 193 ft. and 434 ft.		
Fine to coarse sand			Gravel pack? <input checked="" type="checkbox"/> Size range of material 4.4 mm		
Coarse sand and fine gravel			11. Static water level: mo./day/yr. 196 ft. below land surface Date 4-14-76		
Hard streaks caliche			12. Pumping level below land surfaces:		
Coarse to medium gravel			208 ft. after 3 hrs. pumping 1557 g.p.m.		
Tan and white clay			212 ft. after 1 hrs. pumping 2005 g.p.m.		
			Estimated maximum yield 3000 g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date ___		
			14. Well head completion: ___ Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
			15. Well grouted? yes With: ___ Neat cement <input checked="" type="checkbox"/> Bentonite ___ Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: Unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes ___ No		
			17. Pump: Not installed Manufacturer's name Layne & Bowler Model number 14TL HP 200 Volts Length of drop pipe 280 ft. capacity 2200 g.p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other		
(Use a second sheet if needed)					
18. Elevation: Topography: ___ Hill <input checked="" type="checkbox"/> Slope ___ Upland ___ Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name Garden City, Kansas License No. _____ Address _____ Signed [Signature] Date 1 Dec 76 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5