


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 1	Township number T 31 S R	Range number 33 E/W
2. Distance and direction from nearest town or city: 7 mi. S of Sublette Street address of well location if in city:			3. Owner of well: Leroy Stapleton R.R. or street: Sublette, KS 67877 City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 26 in. Completion date 1-21-77 Well depth 575 ft.		
5. Type and color of material See attachment			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: 0 Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42 lbs./ft. Dia. 16 in. to 575 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250		
			10. Screen: Manufacturer's name L. B. Foster Type Mill Slot Dia. 16" Slot/gauze .080 Length 120' Set between 575 ft. and 455 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack <input checked="" type="checkbox"/> Yes Size range of material 1/4 x 1/8		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 210 ft. below land surface Date 1-24-77		
			12. Pumping level below land surfaces: 235 ft. after <input type="checkbox"/> hrs. pumping 1451 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: None observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639 Garden City, KS Signed C. L. Bethwell Date 2-16-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME LeRoy Stapleton DATE 12-3-76
 STREET ADDRESS _____ TEST # 2 E. Log
 CITY & STATE Sublette, KS DRILLER Geist
 COUNTY Seward QUARTER SW SECTION 1 TOWNSHIP 31 RANGE 33

LOCATION Approx. 125' W. of Test #1

WELL LOCATION

%	DRILLED FOOTAGE			Description of Strata	Static Water Level
	From	Pay	To		Proposed Well Depth
	0		7	Top soil (hard 4' to 7')	
	7		12	Gray clay, sticky	
	12		34	Brown clay, sticky	
	34		41	Reddish brown sandy clay and few fine sand st.	
	41		48	Brown sandy clay and coarse sand st.	
	48		79	Sand fine to med. coarse, small gravel, drilled loose and ragged, used water	
	79		86	Brown sandy clay, few sticky clay st.	
55	86	53	273	Sand fine to med. coarse, small gravel, few large, drilled loose and ragged, used water, hard ledge at 165'	
	273		283	Brown clay, very sticky and soft	
50	283	30	313	Sand fine to med. coarse, few small gravel, drilled loose and ragged, used water, few clay st.	
	313		317	Brown clay, soft and sticky	
50	317	23	340	Sand fine to med. coarse, few small gravel, drilled loose and ragged, used water	
60	340	21	361	Sand fine to med. coarse, small gravel, drilled loose and ragged, used water	
	361		364	Brown clay, sticky	
60	364	16	380	Sand fine to med. coarse, small gravel, drilled ragged, used a little water	
	380		396	Brown sandy clay, lime rock ledges and few coarse sand st., few sticky clay st.	
	396		409	White sandy clay and brown sandy clay st., drilled tight, few sticky clay st., lime rock ledges, few fine sand st.	
	409		454	Brown sandy clay and fine sand st., drilled loose in places, few sticky clay st.	
40	454	17	471	Brown sandy clay, lime rock ledges and few sandstone st.	
	471		485	Yellow soapstone, sticky, few ledges, few sandstone	
Fair	485	32	517	White and tan sandstone, few soapstone st., drilled loose in places, used a little water, mixed 1 sack of bran and 1 lime	
Very Good	517	30	547	White and tan sandstone, drilled loose in places, mostly firm, used a little water, few soapstone st., had to use pull down a little	

(continued)

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****

