


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Seward	Township name	Fraction NW, SW, SE	Section number 11	Town number 31S	Range number 33W
Distance and direction from nearest town or city: 9 Miles S and 1/2 Mile west of Sublette Street address of well location if in city:				3 Owner of well: Dwayne Lambert Address: R.R. Kismet, Kansas		
Locate with "X" in section below: N  W E S 1 Mile				4 Well depth: 382 ft. Date of completion 4/21/75 Well diameter 28 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Well drilled near TH 1-75 (see attached) which is located 1200' North of SW corner of SE 1/4, Sec. 11, T31S, R33W, Seward County, Kansas				7 Casing: Material Stl Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 382 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer Doerr & Foster Type Louver & Mill slot Dia. 16" Slot/gauze 1/8" Length 187' Set between 195 ft. and 382 ft. Fittings: 1.2 - 9MM Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
(use a second sheet if needed)				9 Static water level: 192 ft. below land surface Date _____		
				10 Pumping level below land surfaces: 201 ft. after 1/2 hrs. pumping 1387 g.p.m. 208 ft. after 1 hrs. pumping 2000 g.p.m. Estimated maximum yield 2500 g.p.m.		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Worthington Model number 14" HP _____ Volts _____ Length of drop pipe 240 ft. capacity 1400 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Company Business name _____ License No. _____ Address Garden City, Ks. Signed [Signature] Date _____ Authorized representative 5-19-75		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

Layne-Western Company, Inc.



Garden City, Kansas 67846

[illegible]

Remarks: