

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction SE 1/4 SW 1/4 SW 1/4	Section number 15	Township number T 31 S R 33 EAW	Range number																								
2. Distance and direction from nearest town or city: 23 Miles north of Liberal			3. Owner of well: Franz Land Company R.R. or street: Box 606 City, state, zip code: Liberal, Kansas																										
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 10px;"> <p>Sketch map:</p> </div> <div> <p>1320' East of SW corner of the SW 1/4, Sec. 15, T31S, R33W, Seward County, Kansas.</p> </div> </div>			6. Bore hole dia. 28 in. Completion date 29 April 76 Well depth 396 ft.																										
<div style="display: flex;"> <div style="flex: 1;"> <p>5. Type and color of material</p> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>Top soil</td> <td>0</td> <td>3</td> </tr> <tr> <td>Tan clay</td> <td>3</td> <td>85</td> </tr> <tr> <td>Fine to coarse sand fine gravel</td> <td>85</td> <td>112</td> </tr> <tr> <td>Tan clay</td> <td>112</td> <td>122</td> </tr> <tr> <td>Fine to coarse sand fine gravel small clay streaks</td> <td>122</td> <td>396</td> </tr> <tr> <td>Sandy clay</td> <td>396</td> <td>418</td> </tr> <tr> <td>Tan clay</td> <td>418</td> <td>440</td> </tr> </tbody> </table> </div> <div style="flex: 1;"> <p>10. Screen: Manufacturer's name Doerr Brown & Foster Type Louvered, Millslot Dia. 16" Slot/gauze 1/8" Length 180 Set between 216 ft. and 396 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3.4mm</p> <p>11. Static water level: 200 ft. below land surface Date 10-28-75</p> <p>12. Pumping level below land surfaces: 210 ft. after 1/2 hrs. pumping 1060 g.p.m. 225 ft. after 1 hrs. pumping 2660 g.p.m. Estimated maximum yield 2800 g.p.m.</p> <p>13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____</p> <p>14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> _____ Inches above grade</p> <p>15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.</p> <p>16. Nearest source of possible contamination: Unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne & Bowler Model number 14TL HP 150 Volts _____ Length of drop pipe 240 ft. capacity 2200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other</p> </div> </div>				From	To	Top soil	0	3	Tan clay	3	85	Fine to coarse sand fine gravel	85	112	Tan clay	112	122	Fine to coarse sand fine gravel small clay streaks	122	396	Sandy clay	396	418	Tan clay	418	440	<p>7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug</p> <p><input checked="" type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary</p> <p>8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material Stl. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 216 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 219</p>		
				From	To																								
			Top soil	0	3																								
			Tan clay	3	85																								
Fine to coarse sand fine gravel	85	112																											
Tan clay	112	122																											
Fine to coarse sand fine gravel small clay streaks	122	396																											
Sandy clay	396	418																											
Tan clay	418	440																											
18. Elevation:			19. Remarks:																										
<p>Topography:</p> <p><input type="checkbox"/> Hill</p> <p><input type="checkbox"/> Slope</p> <p><input checked="" type="checkbox"/> Upland</p> <p><input type="checkbox"/> Valley</p>			<p>20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 150 Business name License No. _____ Address Garden City, Kansas Signed [Signature] Date 26 May 76 Authorized representative</p>																										

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

31
 33
 15
 SE
 1/4
 1/4
 1/4
 SW
 SW