

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 32	Township number T 31 S R 33 E/W	Range number
2. Distance and direction from nearest town or city: 2. E. & 16 N.			3. Owner of well: Kenneth Pittman		
Street address of well location if in city: of Liberal, Ks.			R.R. or street: 1109 N. Cain		
			City, state, zip code: Liberal, Kansas 67901		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 3/8 in. Completion date _____	
N 1 Mile W E S 1 Mile				Well depth 450 ft. 6-19-76	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material 3/4 Height: Above or below Threading <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 1/2 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia 1 1/2 in. to 450 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 319	
5. Type and color of material		From To		10. Screen: Manufacturer's name L.B. FASTER	
Overburden		0 122		Type Mill 1/2 Dia. 1 1/2	
Sand and gravel		122 185		Slot/gauze 1/25 Length 2 1/2	
Sand and clay		185 216		Set between 170 ft. and 450 ft. _____ ft. and _____ ft.	
Sand and gravel		216 455		Gravel pack? yes Size range of material 1/2 Dwal	
Yellow clay		455 458		11. Static water level: 6 mo./day/yr. 165 ft. below land surface Date 6-27-76	
				12. Pumping level below land surfaces: 190 ft. after 3 hrs. pumping 1800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2000 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.	
				16. Nearest source of possible contamination: ft. _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: _____ Not installed Manufacturer's name Worthington Model number 51M154 HP 450 Volts _____ Length of drop pipe 380 ft. capacity 1800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clements T&E Drilling, Inc 330 Business name License No. Address Box 955 Signed Thelma Date 6/19/76 Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

31
 33
 32
 NE 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5