


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 17	Township number T 31 S R 34	Range number 34
2. Distance and direction from nearest town or city: west of Satanta to Cimarron river bridge first, rd west of Bridge, 3 south, 1/2 east			3. Owner of well: Gail Young / Moscow, KS 67952		
4. Locate with "X" in section below: <div style="text-align: center;">  </div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 9-27-76 Well depth 290 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP 16 PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 291 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. <input type="checkbox"/>		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20' Set between 240 ft. and 260 ft. Perf: 160-240 and 260-290 ft. Gravel pack? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2" DOWN		
			11. Static water level: 79 ft. below land surface Date 9-3-76 mo./day/yr.		
			12. Pumping level below land surfaces: 119 ft. after 3 hrs. pumping 1500 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft. 10		
16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds U.S. Pumps Model number 12JHC HP 125 Volts <input type="checkbox"/> Length of drop pipe 200 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name Box A Garden City, KS License No. <input type="checkbox"/> Address Box A Garden City, KS Signed [Signature] Date 9-27-76 Authorized representative		

T 31 S R 34
 NW SE SW
 1/4 1/4 1/4
 Sec 17

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

GALE YOUNG
SEWARD COUNTY
7-23-76

Location. SW $\frac{1}{4}$ 17-31-34 west of Satnata to Cimmaron River
bridge first road west of bridge 3 south $\frac{1}{2}$ east
static water level- 120'

0 5 Top soil
5 260 Fine to med. sand and gravel
260 275 Fine to med. sand and gravel 10% clay
275 287 Brown sandy clay
287 288 Brown and yellow clay and brown rock

E.D. 290
20 Screen