


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number		
		Stevens	NW SE NE/4	24	T 31 S	R 35 W		
Distance and direction from nearest town or city:			3 Owner of well: L. C. Black					
Street address of well location if in city:			Address: Satanta, Kansas					
Locate with "X" in section below: N  S 1 Mile			Sketch map:			4 Well depth: <u>295</u> ft. Date of completion <u>8-26-75</u> Well diameter <u>9 7/8</u> in.		
2			Type and color of material			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> stock		
						7 Casing: Material <u>RMP</u> Height: above/ below <u>land</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>24</u> in. Diam. <u>5</u> in. to <u>295</u> ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>5</u> in. to <u>295</u> ft. depth!		
						8 Screen: Manufacturer <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/8"</u> Length <u>30'</u> Set between <u>242</u> ft. and <u>295</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>		
						9 Static water level: <u>147</u> ft. below land surface Date <u>8/4/75</u>		
						10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>50</u> g.p.m.		
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
						12 Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
						14 Nearest source of possible contamination: ft. <u>100</u> Direction <u>S</u> Type <u>well</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
						15 Pump: <u>Windmill</u> <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe <u>235</u> ft. capacity <u>3</u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other		
						16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Friesen Windmill</u> <u>252</u> Business name License No. Address <u>Meade, Kansas</u> <u>67864</u> Signed <u>[Signature]</u> Date <u>9-7-75</u> Authorized representative		