

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County STEVENS	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 2	Township number T 31 S	Range number R 36 E/W
2. Distance and direction from nearest town or city: 3 N - 1 E 1/2 m.		3. Owner of well: Earl Clark		R.R. or street: R. R.	
Street address of well location if in city: 05 Moscow Ka		City, state, zip code: Moscow Kansas 67952			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 10 in. Completion date 12-15-76 Well depth 324 ft.
top soil gray light			0	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
tan silt soil mealy			2	12	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
sand silty			12	16	9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC Sch. 40 Weight _____ lbs./ft. Dia. 5 in. to 324 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 250
clay sticky tan in collar			16	114	10. Screen: Manufacturer's name Stocum Type saw cut Dia. 5" Slot/gauze 1/8 Length 40' Set between 240 ft. and 260 ft. 304 ft. and 324 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 - 1/4
clay w/ gravel			114	130	11. Static water level: _____ mo./day/yr. 205 ft. below land surface Date 12-14-76
sand w/ gravel calcified in spots			130	140	12. Pumping level below land surfaces: 208 ft. after 2 hrs. pumping 23 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
clay stringers w/ gravel (conce.)			140	146	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
clay stringers w/ caliche + some gravel			146	220	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade
gravel / clay to coarse sand			220	240	15. Well grouted? <input checked="" type="checkbox"/> With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 3 ft. to 10 ft.
sand calcified			240	250	16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No
gravel w/ coarse sand			250	290	17. Pump: _____ Not installed Manufacturer's name Roda Model number 19DHP201 HP 2 Volts 230 Length of drop pipe 250 ft. capacity 23 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other _____
clay w/ gravel + sand			290	330	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Stocum well Drilling 127 Business name _____ License No. _____ Address Hugoton Kansas Signed Paul Stocum Date 12-21 Authorized representative
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

31 36 2 NE NE SW 1/4 1/4 1/4