

Inc
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Hubert A. Lewis
8-21-87
Stevens County

Location: NW $\frac{1}{4}$ E-31-37 - Ulysses to Grant-Stevens
Co. Line - $\frac{1}{2}$ S. & 600'
east on north side of house
Static Water Level 196'

Test #1

0 2 Top soil
2 22 Brown clay
22 27 Fine sand
27 68 Brown clay
68 82 Fine to medium sand & gravel - tight - 10% clay
82 94 Fine to medium sand & gravel - hard - 10% clay
94 114 Fine to medium sand & gravel
114 127 Brown clay
127 146 Brown clay - small gravel strip - hard spot
146 163 Brown clay
163 168 Fine to medium sand & gravel
168 179 Brown clay
179 203 Fine to medium sand & gravel - loose
203 225 Brown clay
225 245 Fine to medium sand & gravel - 10% clay
245 295 Fine to medium sand & gravel - tight
295 307 Brown clay
307 320 Brown clay - small streak of gravel - mixed

320' Well
12 $\frac{1}{2}$ " Hole
6-5/8" steel casing
260' Plain
60' Perf.
2 Yards gravel