

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County STEVENS	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 8	Township number T 31 S	Range number R 37 W
2. Distance and direction from nearest town or city: on Hiway 270 to Count Line 2 south 1 west			3. Owner of well: Warren pikes			
Street address of well location if in city: 1/4 north			R.R. or street: Hugoton, KS			
4. Locate with "X" in section below:			Sketch map:			6. Bore hole dia. 26 in. Completion date 6-24-76 Well depth 412 ft.
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					<input checked="" type="checkbox"/> Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft.	
					Dia. 16 in. to 413 ft. depth, Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. 219	
					<input checked="" type="checkbox"/> Screen: Manufacturer's name Johnson Division	
					Type Galv. Dia. 1 1/2" Slot/gauze 100 Length 30'	
					Set between 370 ft. and 400 ft. Perf • 240-370 ft. and 400-412 ft.	
					Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/2" D own	
					11. Static water level: _____ mo./day/yr. 186 ft. below land surface Date 6-15-76	
					12. Pumping level below land surfaces: 204 ft. after 3 hrs. pumping 2250 m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 2250 g.p.m.	
					13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
					14. Well head completion: _____ <input type="checkbox"/> Pitless adapter 12 inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
					17. Pump: _____ Not installed Manufacturer's name Goulds US Pumps Model number 14 JHC HP 200 Volts _____ Length of drop pipe 240 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name _____ License No. _____ Address P.O. box 0A Garden City, KS Signature <i>[Signature]</i> Date 6-22-76 Authorized representative
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

27 376 8 - S E N W S E
 1/4 1/4 1/4 1/4



WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

WARREN SPIGGS
Stevens County
5-17-76

Location: SE 8-31-37 South of Ulysses to Stevens County Line
2 Miles South 1 Mile West 1/4 Miles North
Static Water Level-190

Test #1

0	1	Top Soil
1	52	Brown Clay
52	65	Brown Clay and Fine Sand
65	97	Brown Clay
97	128	Brown Clay and White Rock Tight
128	136	Fine To Med. Sand and Gravel Loose
136	140	Brown Clay
140	229	Fine To Med. Sand and Gravel Loose
229	236	Brown Clay
236	260	Fine To Med. Sand and Gravel Loose
260	277	Brown Clay
277	412	Fine To Med. Sand and Gravel Loose
412	440	Brown clay and Yellow Clay Tight
440	445	Fine To Med. Sand and Gravel Loose
445	462	Brown Gray and Yellow Clay Tight
462	470	Brown Gray Yellow and Red Clay Hard