

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Stevens County	Action <input checked="" type="checkbox"/> NEC NW 1/4	Section number 18	Township number T 31 S	Range number R 37 W
2. Distance and direction from nearest town or city: South of Ulysses to County Line, 2 South, 3 West, 1/2 South, 1/16 East			Owner of well: Warren Spikes (KI) 120 W 6th Hugoton, KS 67951		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 26 in. Completion date 1-30-78 Well depth 463 ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 463 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
			10. Screen: Manufacturer's name Johnson Type Johnson Galv. 100-16" Slot/gauze 0-233 Plain 233-303 Perf. Set between 303-343 Screen 343-463 Perf. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8		
			Static water level: 195 ft. below land surface Date 11-29-77 mo./day/yr		
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
			13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. Inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. ____ Direction N/A Type ____ Well disinfected upon completion? ____ Yes ____ No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name Box A, Garden City, KS License No. 67846 Address: Box A, Garden City, KS Authorized representative: <i>[Signature]</i> Date: 11-29-77			

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

WARREN SPINES
STEELING COMPANY
11-29-77

Location: South of Ulysses to county line, 2 miles south,
3 miles west, 1/2 mile south, 1/16 mile east
NW 13-31-37

Static Water Level: 195'

Test: # 1

0	1	Top soil
1	98	Brown clay
98	115	Fine to med. sand and gravel, 20% clay (loose)
115	140	Fine to med. sand and gravel, 35% clay (loose)
140	163	Fine to med. sand and gravel (loose)
163	177	Brown clay
177	203	Fine to med. sand and gravel (loose)
203	215	Fine to med. sand and gravel, 10% clay (loose)
215	345	Fine to med. sand and gravel (loose)
345	386	Brown clay (tight)
386	395	Fine to med. sand and gravel, 15% clay (loose)
395	420	Brown sandy clay
420	453	Fine to med. sand, 20% clay (tight)
453	575	Red bed (hard)

TD 453'

40' screen