


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Stevens	Fraction NW 1/4 NE 1/4	Section number 25	Township number T 31 S R	Range number 39	EW
2. Distance and direction from nearest town or city: of Moscow, Kansas Street address of well location if in city:			3. Owner of well: Gerald Schmidt R.R. or street: City, state, zip code: Rollo, Kansas 67954				
4. Locate with "X" in section below: 			Sketch map:		6. Bore hole dia. 26 in. Completion date 9/27/77 Well depth 549 ft.		
5. Type and color of material			From		To		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
							8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
							9. Casing: Material Steel Height: 6 ft. or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia. 16 in. to 549 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219
							10. Screen: Manufacturer's name Doerr Type Louvered Dia. 16 " Slot/gauze .050 Length 160 ' Set between 387 ft. and 547 ft. ft. and ft. Gravel pack? Yes Size range of material 3/4" down
							11. Static water level: 190 ft. below land surface Date 9/27/77
							12. Pumping level below land surfaces: 385 ft. after <input type="checkbox"/> hrs. pumping 634 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 500 g.p.m.
							13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
							14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
							15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
							16. Nearest source of possible contamination: None ft. Direction Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name License No. Address Box 639, Garden City, Ks. Signed Bruce J. Richmond Date 10/12/77 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

DRILLERS TEST LOG

CUSTOMERS NAME Gerald Schmidt DATE 8/26/77
 STREET ADDRESS _____ TEST # 1 E. LOG Yes
 CITY & STATE Rollo, Kansas DRILLER Martinez
 COUNTY Stevens QUARTER NE SECTION 25 TOWNSHIP 31 RANGE 39

LOCATION _____

POSSIBLE WELL LOCATION

%	DRILLED		FOOTAGE	Description of Strata	Static Water Level _____
	From	Pay			Proposed Well Depth _____
	(0)		2	Top Soil	
	2		40	Brown sandy clay with a few fine sand sts.	
	40		61	Brown clay	
	61		68	Sand fine to med coarse.	
	68		120	Brown clay	
	120		185	Brown clay with a few lime rock sts.	
50	185	15	200	Sand fine to med coarse. Loose - used water.	
45	200	18	218	Sand fine to med coarse with cemented sts. Used water.	
	218		227	Brown clay	
50	227	11	238	Sand fine to med coarse. Loose - used water. Had a few clay sts.	
	238		243	Brown clay.	
50	243	12	255	Sand fine to med coarse. Loose - used water.	
	255		261	Brown clay	
50	261	20	281	Sand fine to med coarse. Loose - used water.	
	281		320	Brown clay - sticky.	
	320		330	Brown clay with lime rock - hard.	
	330		355	Brown clay with a few lime rock sts. A few fine sand sts.	
50	355	05	360	Sand fine to med coarse. Loose - used water.	
	360		380	Brown clay	
	380		400	Brown clay with a few sand sts.	
Fair	400	60	460	Yellow and white sandstone. Drills loose in places. Used water. Had a few clay sts.	
Good	460	41	501	Yellow and white sandstone. Drills loose - used water.	
	501		520	Yellow clay and soapstone.	
Fair	520	24	544	Soapstone with a few sandstone sts. Drills tight. Used water.	
	544		550	Red bed - hard.	
		206			
				Total Depth 547'	

GARDEN CITY, KS
 PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.

SUBLETTE KS
 PHONE 675-4311

TEST HOLES * * * * * IRRIGATION AND INDUSTRIAL WELLS * * * * * STOCK WELLS