

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Morton	Township name Westola	Fraction S.E. 1/4 at S.E. 1/4	Section number 2	Town number 31	Range number 43
---------------------	-------------------------	---------------------------------	---	----------------------------	--------------------------	---------------------------

Distance and direction from nearest town or city:

Street address of well location if in city:
18 mi. South of Manter


3 Owner of well:

Marvin T. Herron
Address: **Manter, Kans. 67862**

Locate with "X" in section below:

N

Sketch map:



2 Type and color of material

From

To

top soil	1	5
sub-soil	5	25
sandy-clay	25	80
gravel	80	120
sandstone	120	190
blue shale	190	220

4 Well depth: **205** ft. Date of completion _____
Well diameter **13** in.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug
☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry
☒ Irrigation ☐ Air conditioning ☐ Commercial
☐ Test well ☐ _____

7 Casing: Material **PVC** Height: above/below
Threaded ☐ Welded ☐ Surface _____ in.
Diam. _____ Weight _____ lbs./ft. _____
28 in. to **205** ft. depth Drive shoe? ☐ Yes ☐ No
_____ in. to _____ ft. depth

8 Screen:
Manufacturer **Ulysess Irrigation**
Type **1/4" well** Dia. **8"**
Slot/gauze **1/16"** Length **90**
Set between **115** ft. and **205** ft. _____
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material **1/4"**

9 Static water level:
92' ft. below land surface Date _____

10 Pumping level below land surfaces:
100' ft. after **48** hrs. pumping **180** g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield **175** g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date _____

12 Well head completion:
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ neat cement ☐ Bentonite ☐ _____
Depth: From _____ ft. to **2'** ft.

14 Nearest source of possible contamination: **None**
ft. _____ Direction _____ Type _____
Well disinfected upon completion? ☐ Yes ☒ No

15 Pump: ☐ Not installed
Manufacturer's name **Fairbanks Morse**
Model number **75643** HP **7.5** Volts **240**
Length of drop pipe **189** ft. capacity **180** g.m.p.
Type:
☒ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Centrifugal ☐ Other

(use a second sheet if needed)

16 Remarks: elevation

Topography:

☐ Hill
☐ Slope
☒ Upland
☐ Valley

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Delay Drilling 331
Business name _____ License No. _____
Address **Manter Kansas**
Signed **Delay Drilling** Date **5-20-75**
Authorized representative