

1 LOCATION OF WATER WELL:		Fraction	Section Number	Township Number	Range Number
County: <u>Sumner</u>		<u>NE NW NE</u>	<u>15</u>	T <u>32</u> S	R <u>1</u> EW
Distance and direction from nearest town or city street address of well if located within city? <u>22 Westborough, Wellington, KS 67152</u>					
2 WATER WELL OWNER: <u>W.C. Long Jr.</u>					
RR#, St. Address, Box # : <u>22 Westborough</u>				Board of Agriculture, Division of Water Resources	
City, State, ZIP Code : <u>Wellington, KS 67152</u>				Application Number: <u>17</u>	
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>48</u> ft. ELEVATION: <u>—</u>			
		Depth(s) Groundwater Encountered 1. <u>—</u> ft. 2. <u>—</u> ft. 3. <u>—</u> ft.			
		WELL'S STATIC WATER LEVEL <u>21</u> ft. below land surface measured on mo/day/yr			
		Pump test data: Well water was <u>—</u> ft. after <u>—</u> hours pumping <u>—</u> gpm			
		Est. Yield <u>—</u> gpm: Well water was <u>—</u> ft. after <u>—</u> hours pumping <u>—</u> gpm			
		Bore Hole Diameter <u>7 7/8</u> in. to <u>—</u> ft., and <u>—</u> in. to <u>—</u> ft.			
		WELL WATER TO BE USED AS:			
		5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial ⑦ Lawn and garden only 10 Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes <u>—</u> No <u>X</u> ; If yes, mo/day/yr sample was submitted <u>—</u>			
		Water Well Disinfected? Yes <u>X</u> No <u>—</u>			
5 TYPE OF BLANK CASING USED:					
1 Steel		3 RMP (SR)		5 Wrought iron	
② PVC		4 ABS		6 Asbestos-Cement	
				7 Fiberglass	
Blank casing diameter <u>5</u> in. to <u>28</u> ft., Dia				8 Concrete tile	
Casing height above land surface <u>18</u> in., weight <u>160</u> lbs./ft. Wall thickness or gauge No. <u>—</u>				9 Other (specify below)	
TYPE OF SCREEN OR PERFORATION MATERIAL:				CASING JOINTS: Glued <u>X</u> Clamped <u>—</u>	
1 Steel		3 Stainless steel		7 PVC	
2 Brass		4 Galvanized steel		10 Asbestos-cement	
				8 RMP (SR)	
				11 Other (specify)	
				12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:				8 Saw cut	
1 Continuous slot		③ Mill slot		11 None (open hole)	
2 Louvered shutter		4 Key punched		9 Drilled holes	
				10 Other (specify)	
SCREEN-PERFORATED INTERVALS:		From <u>28</u> ft. to <u>48</u> ft.		From <u>—</u> ft. to <u>—</u> ft.	
		From <u>—</u> ft. to <u>—</u> ft.		From <u>—</u> ft. to <u>—</u> ft.	
GRAVEL PACK INTERVALS:		From <u>28</u> ft. to <u>48</u> ft.		From <u>—</u> ft. to <u>—</u> ft.	
		From <u>—</u> ft. to <u>—</u> ft.		From <u>—</u> ft. to <u>—</u> ft.	
6 GROUT MATERIAL:					
1 Neat cement		② Cement grout		3 Bentonite	
Grout Intervals: From <u>0</u> ft. to <u>2</u> ft.		From <u>26</u> ft. to <u>28</u> ft.		4 Other <u>—</u>	
What is the nearest source of possible contamination:					
1 Septic tank		4 Lateral lines		10 Livestock pens	
2 Sewer lines		5 Cess pool		14 Abandoned water well	
3 Watertight sewer lines		6 Seepage pit		15 Oil well/Gas well	
		7 Pit privy		16 Other (specify below)	
		8 Sewage lagoon		13 Insecticide storage	
		9 Feedyard		<u>Don't know</u>	
Direction from well?		How many feet?			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	16	Soil + Clay			
16	33	Clay + Sand			
33	44	Clay			
44	48	Coarse Sand			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>5-6-91</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>504</u> This Water Well Record was completed on (mo/day/yr) <u>6-1-91</u> under the business name of <u>Metz Water Well Service</u> by (signature) <u>Dennis Metz</u>					