

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County BARBER	Fraction NW 1/4 NE 1/4 NW 1/4	Section number 19	Township number T 32 S	Range number R 10 W E/W
2. Distance and direction from nearest town or city: 2 W of Sharon, KS			3. Owner of well: SWEETMAN DRILLING CO			
Street address of well location if in city:			R.R. or street:			
			City, state, zip code: WICHITA, KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 1 July 78		
				Well depth 80 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> Height Above or below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Peerless		
Soil		0	4	Type saw slot Dia. 5"		
CLAY, SANDY RED		4	21	Slot/gauze 1/8 Length 20'		
SAND, FINE Silty		21	30	Set between 60 ft. and 80 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 X 1/4		
Sand, Fine to Coarse & fine gravel		30	47	11. Static water level: 10 ft. below land surface Date 2 July 78		
Clay, Tan & Red w/ sand streaks		47	62	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m.		
Sand, Fine to Coarse & fine to med gravel w/ clay streaks		62	80	_____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.		
Shale, Red		80	90	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: _____ Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: _____ ft. NONE Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other _____		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name License No. _____ Address 121 Sprayer Pratt Signed H. Honomill Date 10 July 78 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: _____ Hill <input checked="" type="checkbox"/> Slope _____ Upland _____ Valley _____						

32
 10
 19
 NW NE NW
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5