

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County BARBER	Fraction NE NE E 1/4 1/4 1/4	Section number 21	Township number 32 T S	Range number 10 R E
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: ARNOLD STEHLEN R.R. or street: Route 1 - Box 3 - Sharon Kansas City, state, zip code: 67138			
* Locate with "X" in section below:		Sketch map: East		6. Bore hole dia. 8 in. Completion date 8-22-77 Well depth 51 ft.		
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 2 feet in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 2 lbs./ft. Dia. 5 in. to 51 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 14		
Top Soil		0	1	10. Screen: Manufacturer's name Jess G. Lowell		
Sand and clay Brown		1	10	Type PVC Dia. 5 Slot/gauze 10 Length 10 Set between 40 ft. and 50 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 14		
Clay and coarse sand		10	20	11. Static water level: mo./day/yr. 11 ft. below land surface Date 8-22-77		
Blue clay		20	30	12. Pumping level below land surfaces: ft. after 1 hr. pumping g.p.m. ft. after 1 hr. pumping g.p.m. Estimated maximum yield g.p.m.		
Sand finest		30	40	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 8-22-77		
Coarse gravel		40	51	14. Well head completion: Well House Pitless adapter 2 feet inches above grade		
Total Depth of well		51 feet		15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 10 ft.		
Had Rock Bottom				16. Nearest source of possible contamination: ft. 100 Direction West Type Human Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean A. Wadsworth 226 Business name _____ License No. _____ Address Chapmanville Kansas Signed Dean A. Wadsworth Date 8-22-77 Authorized representative		
19. Remarks: 4x4 Slab to be installed by customer and well house						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

32-100-21
 W
 1/4
 1/4
 1/4
 1/4
 Sec