

# WATER WELL RECORD (WWC-5) Constructed

WELL ID \_\_\_\_\_

Original Record  Correction  Change in Well Use

## LOCATION OF WATER WELL

Latitude	37.253687	Longitude	-98.588376	Section	23	Township	32 S	Range	12	<input type="checkbox"/> E <input checked="" type="checkbox"/> W	Fraction	NE ¼	NE ¼	NE ¼
Datum		Elevation		County	Barber									

## WATER WELL OWNER

Name	Jeff Guy
Business	
Address	PO Box 399 Reidville SC 29375
Well location	Hwy 160 and Hwy 281. Go South 1.5 miles and east into 490 feet.
<input type="checkbox"/> at owner's address	

## WELL WATER USE

Domestic-Livestock

## COMPLETION

Depth of completed well: 114 ft.  
 Depth(s) groundwater encountered:  
 (1) \_\_\_\_\_ ft.; (2) \_\_\_\_\_ ft.;  
 (3) \_\_\_\_\_ ft.; (4)  dry well

Static water level in well: 25 ft.  
 measured below land surface on (mm/dd/yy): \_\_\_\_\_  
 measured above land surface on (mm/dd/yy): \_\_\_\_\_

Estimated yield: 2 gpm  
 Water level was: \_\_\_\_\_ ft. after \_\_\_\_\_ hours pumping \_\_\_\_\_ gpm

Pump installed?  Yes  No

Water well disinfected?  Yes  No  
 Date disinfected (mm/dd/yy): \_\_\_\_\_

Aquifer, if known: \_\_\_\_\_

## NEAREST SOURCE OF POTENTIAL CONTAMINATION

Source: Surface water body  
 Distance from well: 70 ft. Direction from well: E

Source description: Creek

Source: \_\_\_\_\_  
 Distance from well: \_\_\_\_\_ ft. Direction from well: \_\_\_\_\_

Source description: \_\_\_\_\_

No potential source of contamination within 100 feet.

## CONSTRUCTION

Borehole interval: from 0 to 114 ft. Borehole diameter: 10 5/8 in.  
 from \_\_\_\_\_ to \_\_\_\_\_ ft. \_\_\_\_\_ in.

Casing height above land surface: 24 in.  
 If casing height is less than 12 in. has a variance been approved?  Yes  No  
 \*variance not required for monitoring or environmental remediation wells  
 Casing type: Thermal Plastics (ex. PVC)

Blank casing interval: 0 ft. to 52 ft.  
 Blank casing diameter: 5 in.  
 Casing joints: Glued  
 Weight: \_\_\_\_\_ lbs/ft.  
 Wall thickness or gauge no.: \_\_\_\_\_

Blank casing interval: 92 ft. to 72 ft.  
 Blank casing diameter: 5 in.  
 Casing joints: Glued  
 Weight: \_\_\_\_\_ lbs/ft.  
 Wall thickness or gauge no.: \_\_\_\_\_

Grout interval: 0 ft. to 21 ft.  
 Grout material: Bentonite

Grout interval: \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
 Grout material: \_\_\_\_\_

Screen/perforation material: PVC  
 Screen/perforation openings: Mill slot

Screen/perforation intervals:  
 From 52 ft. to 72 ft. Slot size \_\_\_\_\_ unit \_\_\_\_\_  
 From 92 ft. to 112 ft. Slot size \_\_\_\_\_ unit \_\_\_\_\_

Gravel pack intervals:  
 Gravel pack not used:  Gravel size \_\_\_\_\_ in  
 From 21 ft. to 114 ft.  
 Gravel pack not used:  Gravel size \_\_\_\_\_ in  
 From \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

## PERMIT & ID NUMBERS (AS REQUIRED)

DWR Application No.: \_\_\_\_\_  
 KDHE / EPA Project Code: \_\_\_\_\_  
 Site Name: \_\_\_\_\_  
 KDHE UIC Class V Form Completed:  Yes  No  
 County Permit:  Yes  No Permit ID: \_\_\_\_\_  
 Lease Name & Well #: \_\_\_\_\_  
 # of boreholes: \_\_\_\_\_ # of dewatering wells: \_\_\_\_\_


To	From	Soil Constituent or Rock Type	LITHOLOGIC LOG	Other Details
0	3	Sand	Sandy Top Soil	
3	35	Clay	Gray Clay	
35	50	Clay	Red Clay	
50	114	Shale	Red Shale	

## COMMENTS

(Attach lithologic log if more rows are needed)

Plain Casing From 112 ft to 114 ft

## CONTRACTOR'S OR LANDOWNERS CERTIFICATION

This water well was constructed  reconstructed  pursuant to the stated water well contractor's license and was completed on 12-28-2022. I certify that this record is true to the best of my knowledge and belief. This water well record was completed on 1-23-2023 under the business name of Crowdis Water Well  
 Kansas Water Well Contractor's License No. 672 under the authority of the designated person as defined in K.A.R. 28-30-2(j) and signed and certified by the electronic signature of the designated person at its submittal: 

Send one copy to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well.