

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

32 19 W 11 SE 4 NW
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Comanche	Township name Coldwater	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 11	Town number T32S	Range number R19W
Distance and direction from nearest town or city: 1.5 W, .25 N of Coldwater, Kans.				3 Owner of well: Richard Bind Address: 604 Route Coldwater, Kans.		
Locate with "X" in section below:		Sketch map:		4 Well depth: 58 ft. Date of completion 10/12/74 Well diameter 8.5 in.		
				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
2		Type and color of material		From	To	7 Casing: Material Pipes Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 9/16 Weight 300 lbs./ft. 5 in. to 58 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No ___ in. to ___ ft. depth!
		Sandy top soil		0	5	8 Screen: Manufacturer Sunflower Plastics Type RMP Dia. 5 in slat gauze .06 Length 15ft. Set between 43 ft. and 58 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 4-4
		Sand + Clay		9	38	9 Static water level: 15 ft. below land surface Date ___
		Sand + Gravel		38	58	10 Pumping level below land surfaces: ___ ft. after ___ hrs. pumping ___ g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 10 g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ___
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> ___ Depth: From 1 ft. to 10 ft.
						14 Nearest source of possible contamination: None in Area ft. ___ Direction ___ Type ___ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name ___ Model number ___ HP ___ Volts ___ Length of drop pipe ___ ft. capacity ___ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other Windmill
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Lehl & Son 141 Business name License No. Address Alva, Okla Signed Carl Lehl Date 11/10/75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

32 19 W 11 SE 4 NW