

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

MT. JEFFERSON

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

BAD

1. Location of well: County CLARK		Fraction SE NE NW NW 1/4 SE 1/4 NE 1/4		Section number 5	Township number 32	Range number 21
2. Distance and direction from nearest town or city: 2.2 South Bucklin 3/4 miles East				3. Owner of well: Willis Harden R.R. or street: Ashland, KS City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 30 in. Completion date 2-10-77 Well depth 105 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
fine top sand		0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
water gravel w/some clay streaks.		4	105	9. Casing: Material IRON Height: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 105 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
				10. Screen: Manufacturer's name OPERR METAL Type IRPN Dia. 16 Slot/gauze 3/16 Length 40' Set between 65 ft. and 105 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4 x 5/8		
				11. Static water level: <u>mo./day/yr.</u> 20 ft. below land surface Date 2-10-77		
				12. Pumping level below land surfaces: 80 ft. after 2 hrs. pumping 700 g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield 700 g.p.m.		
				13. Water sample submitted: <u>mo./day/yr.</u> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12" inches above grade		
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: none ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <u>Not installed</u> Manufacturer's name Gould Pump Model number <u>HP</u> 70 Volts <u>Length of drop pipe</u> 165 ft. capacity <u>g.p.m.</u> Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: Well is along Bluff Creek. A booster for existing small well. RB 1983 105 1878			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Albert Bray & Son Dr. 217 Business name <u>License No.</u> Address Box 56, Bucklin, KS Signed Albert Bray Date 4-1-77		

32
T
21
R
5
SE
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5