

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

LEXINGTON

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DAA

1. Location of well: County CLARK Franklin NE 1/4 NE 1/4 SE 1/4 Section number 5 Township number T 32 S R 21 E 0 Range number	
2. Distance and direction from nearest town or city: 16 1/2 SOUTH - 3/4 M EAST BUCKINGHAM 3. Owner of well: WILLIS HARDIN R.R. or street: ASHLAND KS City, state, zip code: ASHLAND KS	
<p>Locate with "X" in section below:</p>	
6. Bore hole dia. 6 7/8 in. Completion date NOV 5, 78 Well depth 67 ft.	
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material IRON Height: 92 Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 92 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 6 7/8 in. to 67 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
10. Screen: Manufacturer's name DOERR METAL PROD. Type TRON Dia. 16 1/4 Slot/gauze 3/16 Length 20' Set between 3/47 ft. and 67 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 X 5/8	
11. Static water level: 37 ft. below land surface Date NOV 2, 78 mo./day/yr.	
12. Pumping level below land surfaces: 48 ft. after 9 hrs. pumping 450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 600 g.p.m.	
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
16. Nearest source of possible contamination: 1/4 ft. Direction EAST Type CORCH Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name GORRAN Model number 11/11 HP 50 Volts <input type="checkbox"/> Length of drop pipe 65 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: FLAT <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: TOPO 2250 67 2183
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. BRAD DRIG 217 Business name BUCKINGHAM License No. Address BUCKINGHAM Signed [Signature] Date 7-1-10 Authorized representative	

T 32 S R 21 E 0
Sec 5
NE 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5