


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

LEXINGTON

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Permit No 79-237 CWW 16432 DB Harden #1-9

1. Location of well:		County Clark	Fraction DE C-NW SE 1/4	Section number 9	Township number T 32 S R 21 E/W	Range number
2. Distance and direction from nearest town or city: From Ashland 6 mi E. then 4mi E. 4 1/2 mi N. 1 1/2 mi west to location			3. Owner of well: Sage Drilling R.R. or street: 222 Sutton Place City, state, zip code: Wichita, Kansas 67202			
4. Locate with "X" in section below: 			6. Bore hole dia. <u>9</u> in. Completion date <u>11-6-79</u> Well depth <u>80</u> ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Surface			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Fine sand			9. Casing: Material <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>28</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2.78</u> lbs./ft. Dia. <u>5</u> in. to <u>40</u> ft. depth Wall thickness inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>256</u>			
Clay			10. Screen: Manufacturer's name <u> </u> Type <u>Saved PVC</u> Dia. <u>5"</u> Slot/gauze <u>.030</u> Length <u>40</u> Set between <u>40</u> ft. and <u>80</u> ft. ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/8-3/16</u>			
Medium to large sand & gravel			11. Static water level: <u>23</u> ft. below land surface Date <u>11-6-79</u> mo./day/yr.			
Red bed			12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>60</u> g.p.m.			
BROCK 67'			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>			
23 44' sat thick			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>28</u> inches above grade			
in Alluvium			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
(Use a second sheet if needed)			16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>N.E.</u> Type <u>Oil well</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
18. Elevation:			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
19. Remarks: TOPO			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>118</u> Carlile Water Well Service Business name License No. <u> </u> Address Box AA Liberal, Kansas Signed <u>Edward E. Means</u> Date <u>11-12-79</u> Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

32210-9 C WUSE

2140
67
2073