USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

ASHLAND

WATER WELL RECORD KSA 82a-1201-1215 Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section	number	Township number	Range number	
1. Location of well:	Clark	SE SW /4 NW 1/4	5 W S¥€1/4	19		т 32S s	R 24W	E(W)
2. Distance and dire	ction from nearest town or city: 12	west & 5 no:	rth 3.0	ner of well	· ror	estry, Fish & Ga	a m e Commissi	on
of Ashland, Kansas R.R. or street: South						hwest Regional Office dge City, Kansas 67801		
4. Locate with "X" in section below: N						6. Bore hole dia. 9 7/8. Completion date		
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1						7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary		
						8. Use: Domestic Public supply Industry Irrigation Air conditioning X Stock Lawn Oil field water Other		
						9. Casing: Material PVC Height: Above or below Threaded Welded XX Surface 12 in.		
S 1 Mile						RMP PVC XX Weight 2.8 lbs./ft. Dia. 5 in. to 113ft. depth Wall Thickness; inches or		
5. Type and color of material				From	То	Diain. to ft. depth gage No265		
				+		10. Screen: Manufacturer's name		
Top soil				0	7	Type		
Clay				 7	40	Set betweenft. andft.		
Med. to lar. sand - lost circulation				40	80	Gravel pack? Yes Size range of material 1/64-5/32		
Med. to lar. sand - with blakk clay				80	110	11. Static water level: mo./day/yr66ft. below land surface Date11/1/77		
No circulation				110	140	12. Pumping level below land	surfaces:	1
		·				ft. after ft. after	hrs. pumping	
				ļ		13. Water sample submitted:		day/yr.
						14. Well head completion: Pitless adapter 24 Inches above grade		
						15. Well grouted? Yes		
BROCK?						With: XX Neat cement Bentonite Concrete Depth: From ft. to 10 ft.		
						16. Nearest source of possible contamination: NONE ft Direction Type		
						Well disinfected upon comple	etion? Yes Yes	No
						17. Pump: Manufacturer's name Model number Windmil	Not installed	
	100000000000000000000000000000000000000					Length of drop pipe105		g.p.m.
						Type: Submersible	Turbine	
(Use a second sheet if needed)						Jet Centrifugal	Reciproc	ating S
18. Elevation: 19. Remarks:						20. Water well contractor's certification:		
						This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: Hill Slope 2293					L	Friesen Windmill 252. Business name License No.		
XX Upland						Address Meade Ka	nsas 6786	54 🕏
Valley						Oxuthorized rep	resentative	4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5