

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction C B A 3/4 1/4 NW 1/4 NE 1/4	Section number 2	Township number T 32 S	Range number R 27 E/W	
2. Distance and direction from nearest town or city: 5 1/2 east & 3/4 north of Meade Street address of well location if in city:			3. Owner of well: Ross Bros R.R. or street: Meade, Kansas City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date _____ Well depth <u>210</u> ft. <u>7-30-75</u>		
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>16</u> in. to <u>210</u> depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.188</u>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>W.A. Brown Free-flo</u>	
Surface			0	3	Type: <u>17%</u> Dia. <u>16</u>	
Green and brown clay			3	61	Slot/gauze <u>1/8</u> Length <u>120</u>	
1/2 med. sand and gravel			61	63	Set between <u>90</u> ft. and <u>210</u> ft.	
Sandy coleche clay			63	86	Gravel pack? <u>yes</u> Size range of material <u>1/2 down</u>	
Good sand and gravel (dry)			86	94	11. Static water level: _____ mo./day/yr. <u>92</u> ft. below land surface Date <u>6-5-76</u>	
Sandy coleche clay			94	101	12. Pumping level below land surfaces: <u>200</u> ft. after <u>2</u> hrs. pumping <u>550</u> g.p.m.	
Good med. sand and gravel			101	113	_____ ft. after _____ hrs. pumping _____ g.p.m.	
Brown clay with 40% gravel mixed			113	115	Estimated maximum yield <u>550</u> g.p.m.	
Good med. sand and gravel			115	123	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Sandy brown coleche clay			123	146	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
Fine sand with 35% clay mixed			146	152	15. Well grouted? <u>No</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete	
Sandy brown clay			152	160	Depth: From _____ ft. to _____ ft.	
1/2 Med, sand and gravel with 20% clay mixed			160	165	16. Nearest source of possible contamination: <u>NA</u> ft. _____ Direction _____ Type _____	
Brown clay with 25 to 30% fine sand			165	173	Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
A-1 med. sand and gravel			173	193	17. Pump: <input checked="" type="checkbox"/> Not installed	
Yellow clay with rock stringers			193	205	Manufacturer's name _____ Model number _____ HP _____ Volts _____	
Red shale <u>BAZOS 7m</u>			205	210	Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation: <u>2505</u> <u>7m</u> Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: <u>10' of grout and pump slab to be installed by customer-he knows this is a regulation</u> <u>Wayne Ross</u> <u>2505</u>				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Acc Hi International</u> <u>190</u> Business name License No. Address <u>Dodge City, Kansas</u> Signed <u>Carl G. Jiral</u> Date <u>8-28</u> Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

T 32 S
 R 27 E/W
 Sec 2
 1/4 1/4 1/4