


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Meade		Fraction A NE_{1/4} B NW_{1/4} C SW_{1/4}		Section number 19	Township number T 32 S R	Range number R 27 X W
2. Distance and direction from nearest town or city: 3 S., 1 E. of Meade Street address of well location if in city:				3. Owner of well: Elmer Friesen R.R. or street: City, state, zip code: Meade, Ks. 67864		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 9 7/8 in. Completion date Well depth 275 ft. 7-7-79		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Top Soil		0	8	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		8	41	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 275 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .265		
Fine Sand		41	50	10. Screen: Manufacturer's name Pump Co		
Green Sandy Clay		50	73	Type PVC Dia. 5" Slot/gauze fine Length 80' Set between 195 ft. and 275 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.		
Fine Sand		73	90	Gravel pack? <input checked="" type="checkbox"/> YES Size range of material #1 fine		
Red Clay & limestone streaks		90	108	11. Static water level: 122 ft. below land surface Date 7-3-79 mo./day/yr.		
Red sandy clay with limestone		108	195	12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 50+ g.p.m.		
Red Clay		195	200	13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Sandy Clay		200	238	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ inches above grade		
Med. to Lar. Sand		238	275	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.		
Clay		275	280	16. Nearest source of possible contamination: ft. 150 Direction S Type windmill well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
WD-275'				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Aermotor Model number SD19 HP 2 Volts 220 Length of drop pipe 210 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Friesen Windmill 252 Business name License No. Address Meade, Kansas 67864 Signed [Signature] Date 11-26-79 Authorized representative		
18. Elevation: Topography: ____ Hill ____ Slope <input checked="" type="checkbox"/> Upland ____ Valley	19. Remarks: 52 ym 2526 2404					

32
22
19
NE 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5