


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction N 1/4 Sec 9 T 32 S R 28 E	Section number 1	Township number 32	Range number 28	E/W E
2. Distance and direction from nearest town or city: 4 East .3 North Meade Street address of well location if in city:				3. Owner of well: Pete Cornelson R.R. or street: Meade, Kansas City, state, zip code:			
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 28 in. Completion date 1-8-77 Well depth 327 ft.			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
9. Casing: Material Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.66 lbs./ft. Dia. 16 in. to 327 ft. depth Wall Thickness 1.88 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>				10. Screen: Manufacturer's name Cook & W.A. Brown Inc. Type Free-flo & Cook 16 Slot/gauze 1/8 Length 310 Set between 17 ft. and 327 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 3/8 CMA			
				11. Static water level: 12 ft. below land surface Date 12-10-76 mo./day/yr.			
12. Pumping level below land surfaces: 200 ft. after 3 hrs. pumping 800 g.p.m. 200 ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 850 g.p.m.				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> <input type="checkbox"/> Inches above grade			
15. Well grouted? No With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.				16. Nearest source of possible contamination: ft. 2000 Direction South Type gas well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 12 JLC HP 125 Volts <input type="checkbox"/> Length of drop pipe 305 ft. capacity 700 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				19. Remarks: 10' of concrete and pump base to be installed by customer-he knows this is a regulation Pete Cornelson			
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name Dodge City, Kansas License No. <input type="checkbox"/> Address <input type="checkbox"/> Signed Gail G. Stitt Date 2-9-77 Authorized representative							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5