

USE TYPEWRITER OR BALL POINT-PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Meade</u>		Fraction <u>A</u> <u>C</u> <u>C</u> <u>NE 1/4 SW 1/4 SW 1/4</u>		Section number <u>23</u>	Township number <u>T 32 S R 28</u>	Range number <u>EW</u>
2. Distance and direction from nearest town or city: <u>2.7 mi south-1/4 east of Meade, Ks</u> Street address of well location if in city:				3. Owner of well: R.R. or street: <u>Roy Seybert</u> City, state, zip code: <u>Meade, Kansas</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>2-28-77</u> Well depth <u>302</u> ft. <u>Plugged to 201</u>		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material <u>Metal</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>10</u> in. RMP <u>16</u> PVC <input type="checkbox"/> Weight <u>31.66</u> lbs./ft. Dia. <u>16</u> in. to <u>302</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>188</u>
Surface				0	3	10. Screen: Manufacturer's name <u>W.A. Brown Free-flow</u> Type <u>10% Free-flow</u> Dia. <u>16</u> Slot/gauze <u>1/8</u> Length <u>160</u> Set between <u>63</u> ft. and <u>183</u> ft. <u>262</u> ft. and <u>302</u> ft. Gravel pack? <u>yes</u> Size range of material <u>CMA</u>
Brown and green coleche clay				3	30	11. Static water level: <u>8</u> ft. below land surface Date <u>2-25-77</u> mo./day/yr.
Gray clay				30	54	12. Pumping level below land surfaces: <u>65</u> ft. after <u>2</u> hrs. pumping <u>1200</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2000</u> g.p.m.
Fine sand				54	64	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
Half med. sand and gravel				64	73	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade
Brown clay				73	79	15. Well grouted? <u>No</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u> </u> ft.
Good loose half med. sand and gravel				79	93	16. Nearest source of possible contamination: ft. <u>200'</u> Direction <u>North</u> Type <u>Corral</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Brown and red clay				93	121	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Half med. sand and fine gravel				121	128	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Ace-Hi International 190</u> Business name License No. Address <u>Dodge City, Kansas</u> Signed <u>Carl [Signature]</u> Date <u>3-7-77</u> Authorized representative
Brown clay				128	143	<div style="float: right; text-align: right; font-size: 2em; font-weight: bold;"> 32 28 23 NE SW SW 1/4 1/4 1/4 Sec </div>
Good med. sand and gravel				143	169	
Good med. sand and fine gravel				169	179	
Sandy brown clay				179	186	
Fine sand with 15 to 20% clay mixed				186	206	
Sandy brown and white clay				206	221	
Fine sand				221	240	
Sandy brown and white coleche clay				240	266	
Good med. sand and gravel				266	301	
Red shale				301	320	
(Use a second sheet if needed)						
18. Elevation: <u>2409</u> ft Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: <u>10' of groute and pump slab to be installed by customer-he knows this is a regulation</u> <u>2409</u> <u>2401</u> <u>Roy D. Seybert</u>					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5