

| | | | | |
|--------------------------|---|----------------|-----------------|-----------------|
| 1 LOCATION OF WATER WELL | Fraction <u>C</u> <u>C</u> <u>B</u> | Section Number | Township Number | Range Number |
| County: <u>Meade</u> | <u>SW</u> 1/4 <u>SW</u> 1/4 <u>NW</u> 1/4 | <u>25</u> | T <u>32</u> S | R <u>28</u> E/W |

Distance and direction from nearest town or city? From Meade go 3 1/2 mi South East into location Street address of well if located within city?

2 WATER WELL OWNER: Sage Drilling Board of Agriculture, Division of Water Resources
 RR#, St. Address, Box # : 222 Sutton Place Wichita, Kansas 67202 Application Number: T 80-198
 City, State, ZIP Code

3 DEPTH OF COMPLETED WELL: 249 ft. Bore Hole Diameter: 9 in. to ... ft., and ... in. to ... ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
7 Lawn and garden only 10 Observation well
 Well's static water level: 145 ft. below land surface measured on April month 10 day 1980 year
 Pump Test Data: Well water was ... ft. after ... hours pumping ... gpm
 Est. Yield 60 gpm: Well water was ... ft. after ... hours pumping ... gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued ... Clamped ...
 2 PVC 4 ABS 7 Fiberglass 9 Other (specify below) Welded ...
 ... Threaded ...
 Blank casing dia: 5 in. to 140 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.
 Casing height above land surface: 28 in., weight 2.78 lbs./ft. Wall thickness or gauge No. .256

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 7 PVC 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 8 RMP (SR) 11 Other (specify) ...
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 7 Torch cut 9 Drilled holes
 10 Other (specify) ...
 Screen-Perforation Dia: 5 in. to 100 ft., Dia ... in. to ... ft., Dia ... in. to ... ft.
 Screen-Perforated Intervals: From 140 ft. to 240 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 Gravel Pack Intervals: From 60 ft. to 240 ft., From ... ft. to ... ft., From ... ft. to ... ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other ...
 Grouted Intervals: From 0 ft. to 10 ft., From ... ft. to ... ft., From ... ft. to ... ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 Direction from well: North east How many feet 100 ? Water Well Disinfected? Yes ... No
 Was a chemical/bacteriological sample submitted to Department? Yes No ... If yes, date sample was submitted ... month ... day ... year: Pump Installed? Yes No ...
 If Yes: Pump Manufacturer's name ... Model No. ... HP ... Volts ...
 Depth of Pump Intake ... ft. Pumps Capacity rated at ... gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on April month 10 day 1980 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. # 118
 This Water Well Record was completed on April month 16 day 1980 year under the business name of Carlile Water Well Service, Inc. by (signature) Edward E. Means

| LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: | FROM | TO | LITHOLOGIC LOG | FROM | TO | LITHOLOGIC LOG |
|--|------|-----|-------------------------------------|---------|----|----------------|
| | | 0 | 2 | Surface | | |
| 2 | | 37 | Clay | | | |
| 37 | | 62 | 80% clay & 20% medium to large sand | | | |
| 62 | | 113 | Medium to large sand | | | |
| 113 | | 240 | Fine sand | | | |

ELEVATION: 2542 ft. 145 ft. 2397 ft.

Depth(s) Groundwater Encountered 1. 95 ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
T
32
R
28
E/W
SEC.
35
SW 1/4
SW 1/4
NW 1/4