

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Meade	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 2	Township number T 32 S R 29 E	Range number 29 E
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 3 3/8 in. Completion date _____ Well depth 257 ft. 11-6-80	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
top soil			0	5	9. Casing: Material _____ Height <u>Above</u> or below Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 257 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 402ch	
brown clay			5	95	10. Screen: Manufacturer's name _____ Type PVC Dia. 5-1 Slot/gauze 3/8" Length 40 Set between 217 ft. and 257 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/4" to 1/2"	
gravel			95	120	11. Static water level: _____ mo./day/yr. 161 ft. below land surface Date 11/6/80	
blue clay			120	150	12. Pumping level below land surfaces: 161 ft. after 1 hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 30 g.p.m.	
gravel			150	165	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
blue clay + sand roots			165	198	14. Well head completion: NO <input type="checkbox"/> Pitless adapter _____ Inches above grade	
gravel			198	257	15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
blue clay			↓		16. Nearest source of possible contamination: ft. 100 Direction South Type Corrals Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: See 19 <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe 191 ft. capacity 2 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		Windmill - reciprocating		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Bartel Dily 101A Business name _____ License No. _____ Address Meade Signed Peter Bartel Date 6-22-80 Authorized representative		

T 32 S R 29 E Sec 2 NW 1/4 SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5