

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Meade</b>	Fraction <b>se 1/4 se 1/4 se 1/4</b>	Section number <b>7</b>	Township number <b>T 32 S</b>	Range number <b>R 29 E/W</b>
2. Distance and direction from nearest town or city: <b>4 miles east of Plains</b>				3. Owner of well: <b>Curt Reinert</b> R.R. or street: <b>Prairie Village Trlr Ct</b> City, state, zip code: <b>Dodge City, Kansas 67801</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>9</b> in. Completion date _____ Well depth <b>315</b> ft. <b>1-14-77</b>		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	3	9. Casing: Material <b>plas</b> Height <b>Above</b> or below Threaded _____ Welded <b>gl</b> Surface <b>12</b> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight <b>1.8</b> lbs./ft. Dia. <b>5</b> in. to <b>315</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <b>0.250</b>		
Silty <del>hardy</del> clay		3	9	10. Screen: Manufacturer's name <b>Jess and Lowell</b> Type <b>RMP</b> Dia. <b>5 1/2</b> Slot/gauze <b>1/16</b> Length <b>50</b> Set between <b>260</b> ft. and <b>315</b> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/8</b>		
Brown and caleche clay		9	50	11. Static water level: _____ mo./day/yr. <b>152</b> ft. below land surface Date <b>1-15-77</b>		
Medium sand and fine gravel		50	68	12. Pumping level below land surfaces: <b>160</b> ft. after <b>5</b> hrs. pumping <b>15</b> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <b>15</b> g.p.m.		
Green and brown clay		68	100	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
Medium sand and gravel		100	114	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <b>12</b> inches above grade		
Rock layer		114	115	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From <b>0</b> ft. to <b>13</b> ft.		
Medium sand and fine gravel loose		115	130	16. Nearest source of possible contamination: ft. <b>100</b> Direction <b>west</b> Type <b>septic tank</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No		
Tan clay		130	140	17. Pump: _____ Not installed Manufacturer's name <b>Reda</b> Model number <b>17D9P101</b> HP <b>1</b> Volts <b>220</b> Length of drop pipe <b>256</b> ft. capacity <b>15</b> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other		
Medium white sand		140	150	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Hodde Drilling Co 302</b> Business name _____ License No. _____ Address <b>Route 1 Dodge City,</b> Signed <b>Melvin Hodde Jr</b> Date <b>2-4-77</b> Authorized representative		
Gray clay		150	166			
Medium sand and fine gravel		166	183			
Blue and blue green soft clay		183	225			
Medium coarse sand		225	240			
Rock layer		240	241			
Medium sand (Use a second sheet if needed)		241	255			
18. Elevation:		19. Remarks: <b>Good loose medium sand and fine gravel loose</b> <b>DR?</b>				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

32  
89  
7-  
SESESE  
1/4  
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5