


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Meade	Fraction SW 1/4 NW 1/4 SW 1/4	Section number 31	Township number T 32 S R 29	Range number E/W
2. Distance and direction from nearest town or city: Approximately 3 miles SE of Plains, Kansas. Street address of well location if in city:			3. Owner of well: Gordon Barnhardt R.R. or street: City, state, zip code: Bucklin, Kansas 67834		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 26 in. Completion date 10/17/78 Well depth 396 ft.
See Attachment					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.96 lbs./ft. Dia. 16 in. to 396 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219
					10. Screen: Manufacturer's name W. A. Brown Type Louvered Dia. 16 " Slot/gauze .125 Length 85 " Set between 290 ft. and 330 ft. 350 ft. and 395 ft. Gravel pack? Yes Size range of material #1 Coarse
					11. Static water level: <input type="checkbox"/> mo./day/yr. 170 ft. below land surface Date 10/19/78
					12. Pumping level below land surfaces: 219 ft. after <input type="checkbox"/> hrs. pumping 1451 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1,500 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					(Use a second sheet if needed)
18. Elevation: x Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name License No. Address Box 639 Garden City, KS Signed Bruce J. Henkle Date 10/20/78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Gordon Barnhardt DATE 4/26/77
STREET ADDRESS _____ TEST # 1 E. LOG Yes
CITY & STATE Bucklin, Ka. DRILLER Martinez
COUNTY Meade QUARTER SW SECTION 31 TOWNSHIP 32 RANGE 29

LOCATION 1340 ft. North of the SW Corner of the SW $\frac{1}{4}$

WELL LOCATION

[illegible]

GARDEN CITY, KS

Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.

IRRIGATION HEADQUARTERS

SUBLETTE, KS

Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * STOCK WELLS