


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--|------------------------|---|---|---|--------------|
| Location of well: | | County <u>MEADE</u> | Fraction <u>NE 1/4 SW 1/4 NE 1/4</u> | Section number <u>31</u> | Township number <u>T 32 S R 29 E/W</u> | Range number |
| Distance and direction from nearest town or city: <u>2nd curve south of Copeland 11 south 5 east</u> | | | | 3. Owner of well: <u>Tom Demmitt</u> R.R. or street: <u>Meade, Ks. 67846</u> City, state, zip code: | | |
| 4. Locate with "X" in section below: | | Sketch map: | | 6. Bore hole dia. <u>26</u> in. Completion date <u>11-30-76</u> Well depth <u>1440</u> ft. | | |
|  | | | | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | |
| 5. Type and color of material | | From | To | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| | | | | 9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>14 1/2</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u> </u> | | |
| | | | | 10. Screen: Manufacturer's name <u> </u> <u>No Screen</u> Type <u> </u> Dia. <u> </u> Slot/gauze <u> </u> Length <u> </u> Set between <u> </u> ft. and <u> </u> ft. Perf. <u>180-1440</u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/2" Down</u> | | |
| | | | | 11. Static water level: <u> </u> mo./day/yr. <u>116</u> ft. below land surface Date <u>10-22-76</u> | | |
| | | | | 12. Pumping level below land surfaces: <u>175</u> ft. after <u>3</u> hrs. pumping <u>1218</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m. | | |
| | | | | 13. Water sample submitted: <u> </u> mo./day/yr. <u>Yes</u> <u> </u> No Date <u> </u> | | |
| | | | | 14. Well head completion: <u> </u> Pitless adapter <u> </u> <u>12</u> inches above grade | | |
| | | | | 15. Well grouted? <u>yes</u> With: <u> </u> Neat cement <u> </u> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft. | | |
| | | | | 16. Nearest source of possible contamination: <u>N/A</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <u> </u> Yes <u>X</u> No | | |
| | | | | 17. Pump: <u> </u> Not installed Manufacturer's name <u>Peerless EMC</u> Model number <u>1143</u> HP <u>200</u> Volts <u> </u> Length of drop pipe <u>240</u> ft. capacity <u>1200</u> g.p.m. Type: <u> </u> Submersible <u>X</u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other | | |
| | | | | (Use a second sheet if needed) | | |
| 18. Elevation: | | 19. Remarks: | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Minter Wilson Drilling 208</u> Business name <u> </u> License No. <u> </u> Address <u>700 Box A Garden City, Ks</u> Signed <u> </u> Date <u>11-16-76</u> Authorized representative | | |
| Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Tom Dimmit
Meade County
9-22-75
NE 1/4 31-32-29

Static Water 140

Location: 1 mile west of Quimbys house 2 miles north

| | | |
|-----|-----|--|
| 0 | 3 | Top soil |
| 3 | 42 | Brown sandy clay |
| 42 | 68 | White & brown sandy clay |
| 68 | 80 | Brown sand clay |
| 80 | 112 | White & brown sandy clay' |
| 112 | 120 | Fine to med sand |
| 120 | 128 | Brown sandy clay |
| 128 | 207 | Fine to med sand & gravel (loose) |
| 207 | 213 | Fine to med sand & gravel streaks of clay (10%) |
| 213 | 228 | Brown sandy clay |
| 228 | 260 | Fine to med sand & gravel streaks of clay (10%) |
| 260 | 287 | Fine to med sand & gravel (loose) |
| 287 | 307 | Fine to med sand & gravel streaks of clay (10%) |
| 307 | 381 | Fine to med sand & gravel (loose) |
| 381 | 410 | Fine to med sand streak of clay (20%)(tight) |
| 410 | 440 | Fine to med sand & gravel (loose) |
| 440 | 460 | Fine to med sand & gravel mixed with brown & grey clay (tight) |
| 460 | 472 | Brown sandy clay mixed with grey clay (tight) |
| 472 | 510 | Fine sand mixed with clay (tight) |
| 510 | 515 | Red clay (hard) |

TD 440'