

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Meade</u>	Township name <u>West Plains</u>	Fraction <u>SW of SW quarter</u>	Section number <u>10</u>	Town number <u>32</u>	Range number <u>30</u>
Distance and direction from nearest town or city:			3 Owner of well: <u>Von Richardson</u>			
Street address of well location if in city:			Address: <u>Plains Kansas</u>			
Locate with "X" in section below:			Sketch map:			
2 Type and color of material			From	To	4 Well depth: <u>320</u> ft. Date of completion <u>6-23-75</u> Well diameter <u>5</u> in.	
<u>Dark Clay</u>			<u>1</u>	<u>20</u>	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>Light Clay</u>			<u>20</u>	<u>40</u>	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
<u>White Clay</u>			<u>80</u>	<u>86</u>	7 Casing: Material <u>Steel</u> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>5</u> in. to <u>5</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No <u>5</u> in. to <u>5</u> ft. depth	
<u>Sand & Gravel</u>			<u>86</u>	<u>190</u>	8 Screen: Manufacturer <u>Sun flower Styrene</u> Type <u>320 mesh</u> Dia. <u>5"</u> Slot/gauze <u>1/16"</u> Length <u>10</u> Set between <u>280</u> ft. and <u>320</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>	
<u>Dark Clay</u>			<u>190</u>	<u>210</u>	9 Static water level: <u>176</u> ft. below land surface Date <u>6-22-75</u>	
<u>sand & Gravel</u>			<u>210</u>	<u>320</u>	10 Pumping level below land surfaces: <u>178</u> ft. after <u>2</u> hrs. pumping <u>15</u> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>60</u> g.p.m.	
<u>Blue Clay</u>			<u>320</u>		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____	
					12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ____ Depth: From <u>18</u> ft. to <u>3</u> ft.	
					14 Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>F+W</u> Model number <u>AB15</u> HP <u>1</u> Volts <u>230</u> Length of drop pipe <u>210</u> ft. capacity <u>10</u> g.m.p. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation <u>There is a septic to be moved in at later date by another contractor location unknown at this time</u>			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Bartel Drilling 101A</u> Business name <u>Meade Kansas</u> License No. ____ Address <u>Meade Kansas</u> Signed <u>Pete R Bartel</u> Date <u>6-23-75</u> Authorized representative			