## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

						,	
Location of well	County	Fraction		Section	number	Township number Range number	
Y rocalion of well	Seward	NE 1/4 NW 1/4 NE	1/4	1/4 15		т 32 s R 32 жажу	
X. Distance and direction from nearest town or city:				ner of well: Norman E. Roehr			
Street address of well location if in city: $4\nu - 5\omega$ R.R. or City, st					Kismet, Kansas 6/839		
Name .					ate, zip code:		
4. Locate with "X" in section below:  Sketch map:						6. Bore hole dia.9_7/8in. Completion date Well depth 380_ ft10-14-76	
<u> </u>						7 Cable tool X_Rotary Driven Dug	
X						Hollow rod Jetted Bored Reverse rotary	
						8. Use: X Domestic Public supply Industry	
						Irrigation Air conditioning Stock	
						Lawn Oil field water Other	
						9. Casing: Material PVC Height: Above or below	
<u> </u>						Threaded Welded iSurface 12 in.  RMP PVC Weight 291 ibs./ft	
S 1 Mile						Dia. 5 in. to 380 ft. depth Wall Thickness: inches or	
5. Type and color of				From	To	Diain. to ft. depth gage No265	
						10. Screen: Manufacturer's name  Jess & Lowell	
Top soil				0	7	Type PVC Dia. 5"	
•						Slot/gauze 1/811 Length 801	
Sandy cla	ay with fine sand			7	100	Set betweenft. andft	
Gravel with clay streaks			100	145	ft. andft Gravel pack? <b>yes</b> Size range of material 3/16"		
					11. Static water level: mo./day/yr		
Sticky greenish clay			145	203	219 ft. below land surface Date 10/7/76		
Medium sand			203	260	12. Pumping level below land surfaces:		
				260	000	ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m.	
Medium sa	Medium sand with blue clay streaks			260	282	Estimated maximum yieldg.p.m	
Medium sa	and			282	390	13. Water sample submitted: mo./day/yr	
01				200	400	Yes X No Date	
Clay				390	400	14. Well head completion: X Pitless agapter unit Inches above grade	
						15. Well grouted? YES	
						With: Neat cement BentoniteX_ Concrete	
			,	1		Depth: From <u>4</u> ft. to <u>14</u> ft.	
		44				16. Nearest source of possible contamination: ft Direction Type	
						Well disinfected upon completion? X Yes N	
				<b>†</b>		17. Pump: Not installed	
						Manufacturer's name <u>Aermotor</u> Model number SD19 HP 2 Volts 220	
						Model number SD19 HP 2 Volts 220 Length of drop pipe 315 ft. capacity 20 g.p.m.	
						Туре:	
	Mission	W				XX_ Submersible Turbine	
	. (Use a second s	heet if needed)				Jet Reciprocating Other	
18. Elevation:	19. Remarks:	noon in noodody				20. Water well contractor's certification:	
to: Elevanon.	171 Northernor					This well was drilled under my jurisdiction and this report	
T						is true to the best of my knowledge and belief.	
Topography: Hill						Friesen Windmill 252 Business name License No	
Slope						Address Meade, Kansas 67864	
X Upland	:					Signed Take True Date # -20	
Valley	,					Authorized representative	