

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction NW¹/₄ NW¹/₄ NE¹/₄	Section number 15	Township number T 32 S R 32 E/W	Range number
2. Distance and direction from nearest town or city: 1 mi. N. 4 W. 4 N 1/2 W of Kismet, Kansas				3. Owner of well: Norman E Roehr R.R. or street: RFD City, state, zip code: Kismet, Kansas 67859		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date 12/14/75 Well depth 375 ft.		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material PITS. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 315 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 0.320		
				10. Screen: Manufacturer's name J+L Type RMP Dia. 5" Slot/gauze 1/16 Length 60 Set between 315 ft. and 375 ft. _____ ft. and _____ ft. Gravel pack? Yes Size range of material 1/8"		
				11. Static water level: _____ mo./day/yr. 212 ft. below land surface Date 12-16-75		
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: ft. 200 Direction West Type Septic Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				18. Elevation:		
				19. Remarks: Well to be Completed by: Andrews Water Well Liberal, Kansas		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T+W Water Well 142 Business name License No. Address Box 816 Liberal, KS Signed Carl Wagoner Date 12/17/75 Authorized representative		

322
 322
 15
 Sec
 1/4
 1/4
 1/4
 NW/4 NE