## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	Combi	T =======		C		Township number   Dance number
1. Location of well:	County	Fraction	Section number		Township number Range number	
	Seward	SB/4 SE1/4 N		2		T 32 S R 32 E/W
2. Distance and direction from nearest town or city: 14N, 5 E,  Street doorest Very location is in city:  Street doorest Very location is in city:  3. Owner R.R. or s City, sta					1	Art Alexander 1801 N. Cain Liberal, Kansas
4. Locate with "X" in section below:  N						6. Bore hole dia. 28 in. Completion date 8-27-76  Well depth 408 ft.
X   X   X   X   X   X   X   X   X   X	NW <sup>1</sup> <sub>4</sub> , Sec. County, K	hhe SE corne 29, T32S, R3 (ansas			đ	7Cable toolRotaryDrivenDugHollow rodJettedBored XReverse rotary  8. Use:DomesticPublic supplyIndustryX_IrrigationAir conditioningStockLawnOil field waterOther  9. Casing: MaterialSt1Height: Above or belowIndustryIrrigationAir conditioningStockLawnOil field waterOther  9. Casing: MaterialSt1Height: Above or belowIndustryIndu
5. Type and color of material				From	То	Diain. toft. depth gage No219  10. Screen: Manufacturer's nameFoster, Doerr
Fine sand				0	13	Type Louver, Millslot 16"
Tan clay				13	30	Slot/gauze
Tan sandy clay				30	53	Gravel pack? X Size range of material 4.4 mm
Fine to medium sand				53	71	11. Static water level: mo./day/yr. 190 ft. below land surface Date 6-23-76
Tan sandy clay				71	94	12. Pumping level below land surfaces: 208 ft. after 2 hrs. pumping 1800 p.m.
Fine to medium sand clay streaks				94	<b>4</b> 75	tr. after hrs. pumping 1809 g.p.m.  Estimated maximum yield 1800 g.p.m.
Red bed				475	500	
				ļ		14. Well head completion: Pitless adapter Inches above grade
				<u> </u>		15. Well grouted? Yes With:Neat cement X Bentonite Concrete
				-		Depth: From _O ft. to _1O ft.
						16. Nearest source of possible contamination:  ft Direction Type
-7						Well disinfected upon completion? X Yes No  17. Pump: Not installed Lavne & Bowler
						Model number 280 700
				<del>                                     </del>		Length of drop pipe ft. capacity g.p.m.  Type: Submersible Turbine
(Use a second sheet if needed)						Jet Reciprocating Other
Topography:  Hill Slope X Upland Valley	19. Remarks:					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  Layne-Western Co., Inc 102 Business name Garden City, Kansas Address Signed  Authorized representative
Forward the white, blu	e and pink copies to the Department	of Health and Environment				Form WWC-5