

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Seward	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 4	Township number T 32 S R	Range number 33 E W
2. Distance and direction from nearest town or city: Approximately 10 miles SE of Satanta, Kansas. Street address of well location if in city:			3. Owner of well: Joe & Phil Dreitz R.R. or street: 15 South Webster City, state, zip code: Liberal, Kansas 67901		
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile 1 Mile			6. Bore hole dia. <u>26</u> in. Completion date _____ Well depth <u>523</u> ft. <u>3/27/79</u>		
5. Type and color of material See Attachment			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>42.06</u> lbs./ft. Dia. <u>16</u> in. to <u>523</u> depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>.250</u>		
			10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Louvered</u> Dia. <u>16"</u> Story gauze <u>.100</u> Length <u>160'</u> Set between <u>297</u> ft. and <u>347</u> ft. <u>367 - 387</u> ft. and <u>430 - 500</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>#1 Fine & #1 coarse</u>		
			11. Static water level: _____ mo./day/yr. <u>202</u> ft. below land surface Date <u>3/30/79</u>		
			12. Pumping level below land surfaces: <u>234</u> ft. after _____ hrs. pumping <u>1429</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>1,500</u> g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: <u>None</u> ft. _____ Direction _____ Type <u>Observed</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: <u>x Flat</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name License No. _____ Address Box 639, Garden City, Ks Signed <u>Bruce J. Richmond</u> Date <u>4/21/79</u> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

