


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Seward	Township name	Fraction SE NW NW	Section number Sec. 8	Town number T32S	Range number R33W	
Distance and direction from nearest town or city: 18 Miles North & 2 miles west of Liberal approx. Street address of well location if in city:				3 Owner of well: Franz Land Company Address: P.O. Box 606 Liberal, Kansas 67846			
Locate with "X" in section below: <div style="text-align: center;">N  S 1 Mile</div>				Sketch map:			
2 Type and color of material				From	To		
				Well drilled near TH 2-75 (see attached),			
				which is located at the center of the NW 1/4,			
				Sec. 8, T32S, R33W, Seward County, Kansas			
				4 Well depth: 320 ft. Date of completion: 5/1/75 Well diameter 28 in.			
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>			
				7 Casing: Material Stl Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 37 lbs./ft. 16 in. to 320 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth			
				8 Screen: Manufacturer Brown & Doerr & Foster louver & Millslot 16" Type Dia. 16" Slot/gauge 1/8" Length 142' Set between 178 ft. and 320 ft. Fittings: 1-9 MM Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material			
				9 Static water level: 84 ft. below land surface Date 3-13-75			
				10 Pumping level below land surfaces: 111 ft. after 1/2 hrs. pumping 1000 g.p.m. 162 ft. after 1 hrs. pumping 3000 g.p.m. Estimated maximum yield 3000 g.p.m.			
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date			
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.			
				14 Nearest source of possible contamination: unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Layne Model number 12K HP 100 Volts 480 Length of drop pipe 180 ft. capacity 900 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co. 150 Business name License No. Address Garden City, Ks. Signed <i>[Signature]</i> Date 5-19-75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

