

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 17	Township number T 32 S R	Range number 33 E (M)
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Scotty Alexander R.R. or street: City, state, zip code: Kismet, ks. 67859			
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 10 5/8 in. Completion date 8/21/79 Well depth 330 ft.			
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 4.0 lbs./ft. Dia. 6 in. to 330 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .316			
<p>See attached log</p>			10. Screen: Manufacturer's name Pumpco Type PVC-slotted Dia. 6" Slot/gauze .040 Length 68' Set between 190-200 ft. and 220-250 ft. 290-310 ft. and 322-330 ft. Gravel pack? Yes Size range of material #1 Fine			
			11. Static water level: 140 ft. below land surface Date 8/21/79 mo./day/yr.			
			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 25 g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade			
			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. 150 Direction west Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			(Use a second sheet if needed)			
			18. Elevation:		19. Remarks:	
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T
R
E
S
E
C
17 NE NE NW
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Scotty Alexander **DATE** 8-20-79
STREET ADDRESS _____ **TEST #** 1 **ELOG NO** _____
CITY & STATE Kismet, Ks. 67859 **DRILLER** Livingston
COUNTY Seward **QUARTER** NW **SECTION** 17 **TOWNSHIP** 32 **RANGE** 33
 Approx. 150' SE of old Well.
LOCATION _____ **WELL LOCATION** HOUSEWELL

#	DRILLED FROM	PAY	FOOTAGE T	DESCRIPTION OF STRATA	STATIC WATER LEVEL	125'
					PROPOSED WELL DEPTH	330'
	0		8	Sand fine to med. small gravel		
	8		12	Brown Clay		
	12		65	Sand fine to med. small gravel. Lost circulation at 51'		
	65		100	Brown Sandy clay & sand st.		
	100		110	Brwon Clay		
65	110	60	200	Sand fine to med. coarse, small gravel		
	200		210	Brown sandy clay & sand st.		
70	210	30	240	Sand fine to med. coarse, small to med. gravel.		
65	240	70	310	Sand fine to med. coarse small gravel. very few clay str.		
	310		325	Brown sandy clay & fine sand st. & lime rock ledges.		
55	325	06	331	Sand fine to med. coarse small gravel		
	331		340	Brown sandy clay & very fine sand st.		
				Lost circulation at 336'		
				Total depth 330'	6" Plastic	
					Perf. plain	
				330-322'	8'	
				322-310'		12'
				310-290'	20'	
				290-250		40'
				250-220'	30'	
				220-200'		20'
				200-190'	10'	
				190-0		190'
					68'	262' TOTAL
				250 lbs Revert		
				#1 fine gravel pack		

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS
 Phone 276-3278

SUBLETTE, KANSAS
 Phone 675-4311

TEST HOLES **DOMESTIC WELLS** **STOCK WELLS** **IRRIGATION & INDUSTRIAL WELLS**