WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Seward	SE 1/4 SE 1/4 SE	1/4	15		т 32 s	_R 34	E.(W)	
Street address of well location if in city: 1 mile S., west side					vner of well: Nelson Yarbrough or street: 514 So. Main state, zip code: Hugoton, KS 67951				
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. — 10 in. Completion date			
475' North and 317' West of SE corner of the SE4, Sec. 15, T32S R34W, Seward County, Kansas.						Well depth 430 ft. 7-25-79 7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary 8. Use: X Domestic Public supply Industry Irrigation Air conditioning Stock			
						Lawn Oi 9. Casing: Material PVC Threaded Welded RMP PVCX	field water Othe 	ow in. bs./ft.	
5. Type and color of material					То	Dia. 5 in. to 330 ft. depth gage No250			
						10. Screen: Manufacturer's name Peerless			
Fine sand				0	4	Type <u>Saw Cut</u> Dia. <u>5¹¹</u> Slot/gauze <u>1/16</u> Length <u>60</u>			
Brown clay				4	38	Set between330ft. and350ft. 390ft. and430ft.			
Fine sand				38	44	Gravel pack? Y Size range of material 1 4 mm 11. Static water level: mo./day/yr.			
Brown clay with sand streaks				44	117				
Medium to coarse sand				117	148	12. Pumping level below land surface: Unknown ft. after hrs. pumping g.p.m.			
White clay				148	168	ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
Medium to coarse sand				168	276	10.14			
White clay with caliche streaks				276	300	14. Well head completion: None			
Blue clay				300	326	Pitless adapter Inches above grade 15. Well grouted? Yes			
Fine to medium sand				326	354	With: Neat cementX Bentonite Concrete Depth: From0 ft. to10 ft.			
Brown and blue clay				354	390	ft Direction Type			
Fine to medium sand				390	436	Well disinfected upon completion? X Yes No 17. Pump: X Not installed			
White and brown clay				436	490	Manufacturer's name			
Red bed				490	500	Length of drop pipe Type:	ft. capacityg		
	(Use a second sh	eet if needed)				Submersible Jet Centrifugal	Turbine Reciproca Other	Se .	
18. Elevation:	19. Remarks:					20. Water well contractor's c This well was drilled under my		port	
Topography: — Hill Slope Upland						is true to the best of my know Layne-Western C Business name Address Garden Cit	ledge and belief. 10., Inc. 10 10., Ks 67846		
Valley						Authorized repr	esentative	7 3 4	