

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <i>Seward</i>	Fraction <i>NE 1/4 NW 1/4 NW 1/4</i>	Section number <i>19</i>	Township number T <i>32</i> S R <i>34</i> E/W	Range number <i>34</i>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
			<i>8 E - 4 S - 1/4 E</i>			
			<i>Moscow, Ka</i>			
			<i>Moscow, Kansas 67952</i>			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>11-18-77</u> Well depth <u>380</u> ft.	
<div style="text-align: center;"> </div>					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface <u>18</u> in. RMP _____ PVC <u>3 1/2</u> 40 Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>380</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>	
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>Pumpco</u> Type <u>saw cut</u> Dia. <u>5"</u> Slot/gauze <u>1/4</u> Length <u>60</u> Set between <u>260</u> ft. and <u>280</u> ft. <u>320 - 340</u> ft. and <u>360 - 380</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/2 - 3/4</u>	
<i>top soil light gray</i>					11. Static water level: _____ mo./day/yr. <u>243</u> ft. below land surface Date <u>11-18-77</u>	
<i>tan silts w/ some caliche + silt balls</i>			<i>3</i>	<i>40</i>	12. Pumping level below land surfaces: <u>245</u> ft. after <u>2</u> hrs. pumping <u>13</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
<i>caliche tan + white</i>			<i>40</i>	<i>52</i>	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
<i>Clay brown sticky</i>			<i>52</i>	<i>66</i>	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> inches above grade	
<i>sand w/ some clay + tan</i>			<i>66</i>	<i>72</i>	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>3</u> ft. to <u>13</u> ft.	
<i>Clays black colored</i>			<i>72</i>	<i>120</i>	16. Nearest source of possible contamination: ft. <u>280</u> Direction <u>W</u> Type <u>septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<i>" + sand</i>			<i>120</i>	<i>136</i>	17. Pump: _____ Not installed Manufacturer's name <u>FW</u> Model number <u>158420</u> HP <u>1 1/2</u> Volts <u>230</u> Length of drop pipe <u>310</u> ft. capacity <u>13</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other	
<i>Clay Tan</i>			<i>136</i>	<i>175</i>		
<i>sand coarse</i>			<i>175</i>	<i>192</i>		
<i>Clay w/ sand + gravel</i>			<i>192</i>	<i>200</i>		
<i>sand + fine gravel</i>			<i>200</i>	<i>228</i>		
<i>Clays w/ some sand fine</i>			<i>228</i>	<i>257</i>		
<i>Clays w/ sand + gravel loose</i>			<i>257</i>	<i>280</i>		
<i>Clays w/ sand medium fine</i>			<i>280</i>	<i>340</i>		
<i>Clays blue w/ sand</i>			<i>340</i>	<i>380</i>		
<i>" " w/ silty sand gray</i>			<i>380</i>	<i>420</i>		
			(Use a second sheet if needed)			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				<u>Stocon Drilling</u> <u>127</u> Business name License No. Address <u>Hugeton, Ka</u> Signed <u>Paul Stocon</u> Date <u>11-21</u> Authorized representative		

32 34 NE 19 NW  
 T S R E Sec  
 1/4 1/4 1/4 1/4