

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Seward	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 35	Township number T 32 S R 34 E/W	Range number
2. Distance and direction from nearest town or city: 11 miles north 4 west of Liberal, Kansas <small>Street address of well location if in city</small>				3. Owner of well: Dwayne Reeve R.R. or street: R.R. City, state, zip code: Liberal, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>28</u> in. Completion date <u>7-24-76</u> Well depth <u>338</u> ft.		
		<p>Center of the SE 1/4, Sec. 35, T32S, R34W, Seward XXXXXX County, Kansas.</p>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Stl.</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>37</u> lbs./ft. Dia. <u>16</u> in. to <u>178</u> ft. depth; Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth; gage No. <u>.219</u>		
Top soil		0	12	10. Screen: Manufacturer's name <u>Foster, Doerr</u> Type <u>Milslot, louver</u> <u>16"</u> Slot/gauze <u>1/8"</u> Length <u>160</u> Set between <u>178</u> ft. and <u>338</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>5mm</u>		
Tan and red clay with sand streaks		12	167	11. Static water level: <u>170</u> ft. below land surface Date <u>6-9-76</u> mo./day/yr.		
Fine to coarse sand fine to medium gravel				12. Pumping level below land surfaces: <u>175</u> ft. after <u>5</u> hrs. pumping <u>1016</u> g.p.m. <u>180</u> ft. after <u>1</u> hrs. pumping <u>2212</u> g.p.m. Estimated maximum yield <u>2300</u> g.p.m.		
with clay streaks		167	338	13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>		
Tan clay with sand streaks		338	380	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>unk</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Layne & Bowler</u> Model number <u>12KL</u> HP <u> </u> Volts <u> </u> Length of drop pipe <u>260</u> ft. capacity <u>800</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 102 Business name <u> </u> License No. <u> </u> Address <u>Garden City, Kansas</u> Signed <u>[Signature]</u> Date <u>18 Nov 76</u> Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T
R
E
S
E
C
1/4
1/4
1/4
1/4
N
U
S
E
S
E

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5