

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Stevens</b>	Township name	Fraction <b>NW NW NE</b>	Section number <b>1</b>	Town number <b>32S</b>	Range number <b>35W</b>
---------------------	--------------------------	---------------	-----------------------------	----------------------------	---------------------------	----------------------------

Distance and direction from nearest town or city: **Approx. 8 mi. E**

**& 1 mi. S. of Moscow**  
Street address of well location if in city:


3 Owner of well:

**University of Kansas  
Lawrence  
Kansas**

Address:

Locate with "X" in section below:

Sketch map:



4 Well depth: **405** ft. Date of completion **3/24/75**  
Well diameter **28** in.

5 ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug  
☐ Hollow rod ☐ Jetted ☐ Bored ☒ Reverse rotary

6 Use: ☐ Domestic ☐ Public supply ☐ Industry  
☒ Irrigation ☐ Air conditioning ☐ Commercial  
☐ Test well ☐

7 Casing: Material **Stl.** Height: above/below  
Threaded ☐ Welded ☒ Surface **12** in.  
Diam. **16** in. to **405** ft. depth Weight **37** lbs./ft.  
Drive shoe? ☐ Yes ☒ No

8 Screen:  
Manufacturer **Doerr & Brown & Foster**  
Type **Louver & Mill slot** Dia. **16"**  
Slot/gauze **1/8"** Length **161**  
Set between **244** ft. and **405** ft.  
Fittings:  
Gravel pack ☒ Yes ☐ No Size range of material **1, 2 - 9 mm**

9 Static water level:  
**238** ft. below land surface Date **2-28-75**

10 Pumping level below land surfaces:  
**268** ft. after **1/2** hrs. pumping **1557** g.p.m.  
**278** ft. after **1** hrs. pumping **1809** g.p.m.  
Estimated maximum yield **2000** g.p.m.

11 Water sample submitted:  
☐ Yes ☒ No Date

12 Well head completion:  
☐ Pitless adapter ☒ Inches above grade

13 Well grouted? ☒ Yes ☐ No  
☐ Neat cement ☒ Bentonite ☐  
Depth: From **0** ft. to **10** ft.

14 Nearest source of possible contamination: **unk**  
ft. Direction Type  
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☐ Not installed  
Manufacturer's name **Layne**  
Model number **12TH** HP **160** Volts  
Length of drop pipe **320** ft. capacity **1800** m.p.  
Type:  
☐ Submersible ☒ Turbine  
☐ Jet ☐ Reciprocating  
☐ Centrifugal ☐ Other

16 Remarks: elevation

Topography:

☐ Hill  
☐ Slope  
☒ Upland  
☐ Valley

17 Water well contractor's certification:  
This well was drilled under my jurisdiction and this  
report is true to the best of my knowledge and belief.

**Layne-Western Co. Inc 150**  
Business name License No.  
Address **Garden City, Ks.**  
Signed **[Signature]** Date **19 May 75**  
Authorized representative

***Layne-Western Company, Inc.***



WICHITA • GARDEN CITY • LIBERAL • KANSAS CITY • DENVER • OMAHA • AMES • ST. LOUIS • AURORA