

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Stevens</u>	Fraction <u>NE 1/4 NW 1/4 NE 1/4</u>	Section number <u>3</u>	Township number T <u>22</u> S R <u>35</u> E/W	Range number
2. Distance and direction from nearest town or city: <u>SE - 25</u> of <u>of</u>				3. Owner of well: <u>Colson John</u> R.R. or street: <u>B.R.</u>		
Street address of well location if in city: <u>Moscow</u>				City, state, zip code: <u>Moscow Kansas 67952</u>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>11-12-75</u> Well depth <u>350</u> ft.		
		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>2-75</u> lbs./ft. Dia. <u>5</u> in. to <u>350</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>350</u> ft. depth gage No. <u>250</u>		
5. Type and color of material				From	To	10. Screen: Manufacturer's name
<u>top soil</u>				<u>0</u>	<u>2</u>	Type <u>Saw cut</u> Dia. <u>5</u> "
<u>tan clay containing some sand</u>				<u>2</u>	<u>60</u>	Slot/gauze <u>1/8</u> Length <u>20</u> "
<u>silt balls + redish silt</u>				<u>60</u>	<u>72</u>	Set between <u>230</u> ft. and <u>250</u> ft.
<u>joint clays + silt</u>				<u>72</u>	<u>138</u>	Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4 - 1/2</u>
<u>clay + sand sand coarse</u>				<u>138</u>	<u>160</u>	11. Static water level: <u>270</u> ft. below land surface Date <u>11-14-75</u>
<u>sand fine to coarse calcified</u>				<u>160</u>	<u>188</u>	12. Pumping level below land surfaces: <u>1200</u> <u>280</u> ft. after <u>2</u> hrs. pumping <u>2</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>2 gal. per ft.</u> g.p.m.
<u>sand fine to coarse w/ clay (gray)</u>				<u>188</u>	<u>194</u>	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
<u>clay + some gravel + sand</u>				<u>194</u>	<u>200</u>	14. Well head completion: <u> </u> <input checked="" type="checkbox"/> Pitless adapter <u>12</u> inches above grade
<u>sand + gravel coarse w/ some clays</u>				<u>200</u>	<u>254</u>	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u> </u> ft. to <u> </u> ft.
<u>clay w/ sand Tan + brown</u>				<u>254</u>	<u>260</u>	16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>NE</u> Type <u>SEPTIC TANK</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
<u>sand + clay " + "</u>				<u>260</u>	<u>292</u>	17. Pump: <u>RODA</u> Not installed Manufacturer's name <u>RODA</u> Model number <u>19D18P</u> HP <u>2</u> Volts <u>230</u> Length of drop pipe <u>310</u> ft. capacity <u>20</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
<u>clay " " "</u>				<u>292</u>	<u>304</u>	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Stearns Drilling 127</u> Business name <u>Box 237 HUGOTON, Kan.</u> License No. <u> </u> Signed <u>Paul Stearns</u> Date <u>11-15</u> Authorized representative
<u>clay + sand</u>				<u>304</u>	<u>320</u>	
<u>sand coarse + fine gravel</u>				<u>320</u>	<u>360</u>	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						